



# SEWAGE DISPOSAL.

BY

HENRY ROBINSON,

M. INST. C.E., F.G.S., F.R.G.S.,

*Author of 'Purification of Water-carried Sewage.'*



LONDON:

E. & F. N. SPON, 46, CHARING CROSS.

NEW YORK:

446, BROOME STREET.

1880.

186. f. 96.



## P R E F A C E.

---

In this book I have endeavoured to indicate briefly and clearly the main facts which govern the question of sewage disposal. Much of the data has been collected when advising sanitary authorities as to the best means of sewerage their towns and of purifying the sewage, or of otherwise disposing of it. In the course of the investigations I have had to make into the several methods for dealing with town refuse, I have had opportunities of collecting data, the condensation of which into a compass convenient for reference, will, it is hoped, afford a ready means of obtaining information on points which are continually arising in sewerage practice.

Some of the contents of this book have appeared, in one form or another, in Papers which I have read before various Societies.

The Official Blue Books and other published information contain much valuable matter, but some of this has either become obsolete, or to enable it to be utilized it requires to be detached from that which is less useful, so far as relates to this subject.

There is now exhibited a better agreement than heretofore on the main points that have to be adhered to in dealing

with sewage. The extravagant expectations, on the part of the advocates of precipitation processes, that fortunes were to be made out of sewage, if treated by a particular system, have died out, and the equally sanguine hopes of irrigationists, that the application of sewage to land would result in pecuniary gain, have also been sobered by experience. In the former case, mistaken views have been exposed at the expense of private capitalists, who have lost their money in Companies, whereas experience in land irrigation, where it was inappropriate, has been gained at the expense of the ratepayers of the towns which have adopted that system.

Where suitable land is available I advise irrigation, but where such is not the case, I employ chemical treatment either in aid of land where too little is obtainable, or as a substitute for it altogether where it cannot be obtained.

I have confined myself in this book to the systems for sewage disposal which are of most importance, and have excluded many which, although interesting, do not, in my judgment, offer a prospect of succeeding or of superseding those I refer to. Information respecting them, however, will be found in the book which I published (in conjunction with Mr. Melliss) in 1877, called 'Purification of Water-carried Sewage.'


I am able to refer in this book to a valuable report which was made in October of last year by Dr. Angus Smith to the Local Government Board, in which is given much useful information as to the results of irrigation, chemical treatment, and the two combined.

This report would have been still more useful and interesting had the effect of irrigation been shown by the

results obtained at more than one town where the system is in continuous operation on a large scale, instead of only at Aldershot, where the sewage is applied only two days out of the seven, and the conditions are exceptional in other respects. The results obtained at towns where chemical treatment is employed, are not open to any objection, as they illustrate the most important processes in continuous operation.

HENRY ROBINSON,  
M. INST. C.E.

7, WESTMINSTER CHAMBERS, LONDON, S.W.,  
*January 1880.*



# CONTENTS.



## CHAPTER I.

	PAGE
INTRODUCTION .. .. .	1

## CHAPTER II.

MEMORANDA ON SEWAGE .. .. .	6
-----------------------------	---

## CHAPTER III.

SEPARATE SYSTEM OF SEWERAGE .. .. .	11
-------------------------------------	----

## CHAPTER IV.

RIVERS POLLUTION (WITH A REFERENCE TO THE THAMES AND THE SEWAGE OF LONDON) .. .. .	13
---	----

## CHAPTER V.

FILTRATION .. .. .	18
--------------------	----

## CHAPTER VI.

IRRIGATION (WITH REFERENCES TO THE SEWAGE OF LONDON, PARIS, AND ALDERSHOT) .. .. .	20
---	----

## CHAPTER VII.

INTERMITTENT DOWNWARD FILTRATION .. .. .	32
--	----



## CHAPTER VIII.

	PAGE
CHEMICAL TREATMENT .. .. .	35

## CHAPTER IX.

LIME PROCESS (INCLUDING SCOTT'S AND HILLE'S) .. .. .	42
--	----

## CHAPTER X.

COVENTRY PROCESS .. .. .	51
--------------------------	----

## CHAPTER XI.

A B C PROCESS .. .. .	56
-----------------------	----

## CHAPTER XII.

SEWAGE SLUDGE .. .. .	61
-----------------------	----

## CHAPTER XIII.

DISCHARGE OF SEWAGE INTO THE SEA .. .. .	66
--	----

## CHAPTER XIV.

COMPARISON BETWEEN IRRIGATION, CHEMICAL TREATMENT, AND THE PRINCIPAL CHEMICAL SYSTEMS .. .. .	70
--	----

## APPENDIX.

TABLE OF RECENT OFFICIAL ANALYSES, SHOWING RESULTS OF, 1ST, IRRIGATION; 2ND, CHEMICAL TREATMENT, <i>per se</i> ; 3RD, CHEMICAL TREATMENT AND LAND IRRIGATION, BY DR. ANGUS SMITH ..	75
ANALYSES OF SUITABLE AND UNSUITABLE LIME FOR SEWAGE TREATMENT BY DR. WILLIAM WALLACE .. .. .	79
TABLE GIVING POPULATION, FLOW OF SEWAGE, AREA OF LAND, COST, &C., AT TWENTY-TWO TOWNS EMPLOYING IRRIGATION ..	80

# SEWAGE DISPOSAL.

---

---

## CHAPTER I.

### INTRODUCTION.

IN this book the consideration of the disposal of sewage will be confined to that portion of the refuse of the community which is conveyed away by the water-carried system of drainage, and it will not include any of the methods known as the dry earth, pail, and other systems.

The disposal of sewage involves to so large an extent the health of the community that it deserves the most thoughtful consideration on the part both of individual householders and of town authorities. A better compliance with the well-recognized rules which govern the subject cannot be too strongly insisted on. A glance at the official tables of death-rates shows a serious proportion of deaths from preventable diseases produced by either defective house sanitation or town drainage. Besides the loss of population thus caused, an enormous number are annually enfeebled in mind and body by these diseases, and they become more or less a burthen to the community! It may be truly asserted that real economy is practised by a town which expends its funds liberally in the direction of sanitary improvements.

Although it is not contended that bad drainage and defective house sanitation alone cause the death-rates in

large towns to be higher than where the populations are less concentrated, nevertheless, they are important factors. The Registrar-General has shown that a population of 12,892,982 persons living on 3,183,965 acres in the districts comprising the chief towns of England, gave an average death-rate for ten years of 24·4 per 1000, whilst a population of 9,819,284 persons living on 34,135,256 acres in districts comprising small towns and country parishes, showed an average death-rate for a similar period of 19·4 per 1000.

It is essential that sewage should be promptly got rid of from the district producing it, and this can only be accomplished by taking care that the sewers are properly constructed both as to shape, capacity, and gradient. These desiderata are frequently not complied with in one or other respect, and, as a consequence, sewers are a source of danger to health, inasmuch as they retain, to a greater or lesser extent, the foul matters which they are intended to remove. The noxious gases liberated from decomposing sewage rise in the sewers and escape at every opening into the dwellings with disastrous effect to the health of the inmates. If proper ventilation is provided, no evil consequences may result, or the dilution may lessen them.

Where the relative proportions of main and contributory sewers have not been properly studied, the velocity of flow is subject to unnecessary variation, and is reduced below that which would suffice to bear onward the solid matter, and thus banks of putrescible substances are formed which are dangerous to health.

A system of sewerage is frequently arranged on the erroneous assumption that the sewage will be delivered into it for transmission at a uniform rate during the twenty-four hours. Sometimes the sewers are too small to admit of their running only two-thirds full (as they should), and they have to run full even during ordinary rainfalls. It is found

best in practice for sewers to be designed to deliver one-half the total daily flow in six hours.

The flow of sewage is at its maximum about midday, and at its minimum at midnight.

Most of the cases of flooding arise from the assumption that the rainfall will be distributed over a greater period than it is, so that when the calculated rainfall for twenty-four hours falls in three hours, the sewer is taxed far beyond its capacity, and serious mischief to property and danger to health accrues.

A remarkable instance of this came to our notice during an investigation in which we were engaged in 1878 with reference to the cause of an epidemic of diphtheria in London in the parishes of Hampstead and Marylebone. At one point of the sewerage system of those districts, and in the centre of the affected area, two sewers, about 6 feet in diameter each (draining a large area), were carried by a double junction into a sewer only 4 feet 10 inches in diameter, which latter sewer subsequently expanded to 7 feet in diameter. The effect of this contraction was to permanently interfere with the regular flow of the contributory sewers, and to create deposits of foul matter in them, causing a general pollution of the air in the district. During heavy rains the sewers became choked, and the neighbourhood was flooded (two floods having occurred in the year 1878).

These sewers were rectified by the Metropolitan Board of Works (who had jurisdiction over them), and when the works were being executed, many months after the epidemic had subsided, several cases of diphtheria occurred in the immediate neighbourhood, confirming the opinion which we expressed at the time, that the polluted condition of the sewers in this district was a factor in regard to the epidemic.

Far too little attention is paid to absolutely trapping each dwelling from direct communication with the sewer into which it drains, and to thoroughly ventilating both the house-drains and the sewer. The most important points for practical guidance in reference to house sanitation are as follows:—

1. House-drains should be effectually trapped from the main sewer.

2. House-drains should, where possible, be laid outside and not under a house; but where this is impossible great care should be taken that the pipes are sound, and well laid with perfectly air and water tight joints. No direct connection with a drain (that is without most careful trapping) should under any circumstances be made inside a house.

3. Sinks should discharge outside the house, on to the surface of a trapped gully on the ground-level having a grating communicating directly with the air.

4. Overflow and waste-pipes from cisterns, tanks, lavatories, baths, &c., should not be carried directly into a drain, soil pipe, or water-closet trap. They should deliver either into a sink cut off from the sewer, or on to the surface of a gully similar to the one already described. The cistern for water-closets should be distinct from that for supplying water for dietetic purposes.

5. Rain-water pipes, where in proximity to windows should be cut off from direct communication with the drain.

6. Soil pipes should, where practicable, be carried outside houses, and should have no places in which foul matter can accumulate. They should be ventilated by being continued to a point above the roof, but away from windows.

7. The connection between the soil pipes and the drains should be by an oblique junction and curved pipe, to effect a prompt removal of the sewage from the vicinity of the house.

8. Water traps should not be solely relied upon as being sufficient without ventilation, as foul gases will pass through the water under sufficient pressure or by condensation and transmission.

9. Every person intending to take a house should require a certificate as to the fulfilment of the above conditions, and should regard such a certificate as essential to his accepting a lease or agreement for a house, and as important as a certificate of its structural safety.

10. The connection between a house and the sewer should be inspected and certified by a competent person before the ground is closed, otherwise there is no protection against the serious evils consequent on either the ignorance or dishonesty of builders.

Parliament should enact that all houses let to the poorer classes should fulfil certain minimum requirements as to drainage, water supply, ventilation, and other essentials. If a certificate from the local sanitary authority was not forthcoming that these requirements had been complied with, the house should be deemed unfit for human habitation. It should be held as important for a house to be wholesome before it is let or sold as for food to be wholesome, and inasmuch as there exists statutory powers under which food that is unfit for consumption is condemned and destroyed, why should there not be similar legislation to meet the case of house property that is unfit for habitation?

## CHAPTER II.

## MEMORANDA ON SEWAGE.

A GALLON weighs 10 lbs.

1 cubic foot weighs 62·4 lbs. and =  $6\frac{1}{4}$  gallons.

1 cubic inch weighs ·036 lbs. and = ·16 cubic feet.

1 cwt. = 1·8 cubic feet = 11·2 gallons.

1 ton = 35·9 cubic feet = 224 gallons.

One inch in depth of sewage over an acre of land is equivalent to 101 tons (or 22,600 gallons).

120 inches in depth of sewage (taken at 25 gallons per head of the population) may be filtered per annum on properly prepared and deeply drained land of a porous character, if it is applied with care and uniformity. This is equivalent to 300 people to the acre; 100 people per acre, however, are taken, as a rule, for broad irrigation.

The average weight of the solid and fluid excreta of a human being is  $2\frac{1}{2}$  lbs. per diem. The urine of 100,000 persons weighs 234,380 lbs., and the fæces of 100,000 persons weigh 15,620 lbs. The fæces or solid portion being to the fluid or urine as 1 to 16.

WEIGHT IN GRAINS OF SOLID AND LIQUID EXCREMENT PER PERSON PER DAY, AND THE ORGANIC NITROGEN AND PHOSPHATES CONTAINED THEREIN, ACCORDING TO DR. FRANKLAND.

	Fæces.	Organic Nitrogen.	Phos-phates.	Urine.	Organic Nitrogen.	Phos-phates.
Men ..	150	1·74	3·23	1500	15·0	6·08
Women ..	45	1·02	1·08	1350	10·73	5·47
Boys ..	110	1·82	1·62	570	4·72	2·16
Girls ..	25	·57	·37	450	3·68	1·78

The average amount per head of the population is 39·1 oz. of moist material, containing 2·2 oz. of solid matter, of which about 291 grains are insoluble in water.

Dr. Letheby ascertained that a gallon of midday London sewage contained 94 grains of solid matter per gallon, 55·7 of which were in solution and 38·2 in suspension. The organic matter was 31·2 grains per gallon, of which 15·1 were dissolved and 16·1 suspended.

Professor Way found, as the result of ninety-eight analyses of Rugby sewage, that a gallon of sewage contained 92·5 grains of solid matter, 29 of which were organic and 63·5 mineral. The nitrogen in the complete analyses amounted to 6·18 grains per gallon, the phosphoric acid to 1·68 grains per gallon, and the potash to 2·81 grains.

Dr. Letheby considered that 1000 persons of a town population contributed 3750 gallons of sewage a day, containing about 167 lbs. of organic matter, 33·3 lbs. of nitrogen, 9·4 lbs. of phosphoric acid, and 6·9 lbs. potash.

A gallon of sewage yields as the mean of analyses by Letheby, Hoffman, Witt, Way, and Voelcker:—

Organic matter	..	..	..	27·72	grains.
Nitrogen	..	..	..	6·21	„
Phosphoric acid	..	..	..	1·57	„
Potash	..	..	..	2·03	„

Dr. Hoffman and Mr. Witt, in 1857, took hourly samples of London sewage from the Savoy Street sewer (which was chosen as giving a fair specimen of London sewage), and mixed these samples to produce an average. This yielded 30·7 grains of organic matter per gallon, 6·76 grains of nitrogen, 1·85 of phosphoric acid, and 1·03 of potash.

Professor Williamson, in September 1877, analysed the metropolitan sewage, at the northern outfall into the River Thames, with the following result, according to a Report by



Captain Calver, F.R.S., on the Discharge of Metropolitan Sewage into the River Thames :—

CONTENTS IN GRAINS PER GALLON.

	One Hour before Low Water.	Two Hours after High Water.
<i>Suspended Matter—</i>		
Organic matter .. .. .	37·24	104·97
Sand .. .. .	44·10	23·52
Iron .. .. .	4·90	1·96
Alumina .. .. .	4·90	8·40
Carbonate of lime .. .. .	12·07	11·20
Oxygen and iron combined with other matters undetermined .. .. .	4·80	1·45
<b>Total suspended solids .. ..</b>	<b>108·01</b>	<b>151·50</b>
<i>Dissolved Matter—</i>		
<b>Total .. .. .</b>	<b>81·00</b>	<b>103·60</b>
Containing common salt .. .. .	43·92	51·88
Ammonia in one gallon of sewage contain- ing suspended and dissolved matters—		
Free .. .. .	4·13	4·09
Albuminoid .. .. .	2·46	4·55
<b>Total .. .. .</b>	<b>6·59</b>	<b>8·64</b>

The following are other official analyses of *London Sewage* :—

	Solids suspended in Grains per Gallon.
Letheby.—Average at all hours from ten large city sewers .. .. .	38·15
Hoffman and Witt.—Average from March to June 1857 .. .. .	42·23
Rivers Pollution Commissioners.—Average from February to June 1869 .. .. .	43·75

Mr. Keates analysed the raw sewage discharged into the Thames at the Southern Metropolitan Outfall, at Crossness,

during August, September, October, and November, 1872, and the mean of twelve analyses is as follows:—

## IN GRAINS PER GALLON.

Total Solids in Solution.	Mineral Matters.	Organic Matter.	Organic Nitrogen as Ammonia.	Ammonia.	Total Nitrogen as Ammonia.
72	61·3	10·7	·265	1·615	1·947

The average amount of solid matter per gallon of sewage may be taken at 90 grains, of which 28 grains are organic and 62 grains inorganic.

Other analyses of sewage are given in the Tables in the Appendix.

Sewage varies in quality, and the ammonia contained in it ranges from  $2\frac{1}{2}$  grains per gallon to upwards of 15 grains per gallon. The chemist's theoretical value is one farthing per ton for each grain of ammonia in one gallon.

An average individual of a town population yields annually 12·6 lbs. of ammonia.

Dr. Letheby considered the constituents of urine when dried to be worth 18*l.* 14*s.* 1*d.* a ton, and of fresh fæces when dried 5*l.* 17*s.* 7*d.* a ton, and the dry matter of both solid and liquid excreta of a mixed population 14*l.* 16*s.* 4*d.* per ton.

A sample of Thames mud (550 cubic centimetres) taken from a mud bank on the north side of Lambeth Bridge, July 10, 1878, was examined by Professor Wanklyn, and consisted of—

Water	..	..	..	..	..	69 parts.
Solids, dry	..	..	..	..	..	31 "
						100

For agricultural purposes, 10 tons of average water-closet sewage may be taken to be equal to 12 tons of sewage from a non-water-closeted town.

To convert parts per 100,000 into grains per gallon, multiply by 7, and remove the decimal point one place to the left.

#### FLOW IN SEWERS.

$x$  = area of sewer + the wetted perimeter in feet.

$f$  = fall in feet per mile.

$V$  = velocity in feet per minute.

$A$  = area in square feet.

$C$  = cubic feet delivered per minute.

$$V = 55 \sqrt{x \times 2f}$$

$$C = V \times A$$

## CHAPTER III.

## SEPARATE SYSTEM OF SEWERAGE.

WHERE the sewage of a town or district cannot be got rid of without its having to be purified on land or by chemicals, it is desirable where possible to exclude from the sewers such part of the rainfall as is free from serious pollution ; and this should be conveyed away by natural drains or watercourses. A heavy rainfall cleanses the surface of roads, yards, gutters, courts, &c., and the first flow of storm water may be very highly charged with pollution. This, of course, would be greatly reduced by a good system of scavenging, such as should exist in large towns.

Notwithstanding the most complete system of scavenging and cleansing, the filth removed from gutters and bye-streets by rain is very great. Analyses of the water flowing in the London gutters after a heavy rain succeeding a dry period, have proved it to be as foul as ordinary sewage as regards the amount of putrescible organic matter it contained.

Where provision can be made for disposing of the surface water, the expense and difficulties attending a system of sewerage are greatly reduced. The sewers can be arranged to carry a volume which is, comparatively speaking, uniform ; consisting as it would of the fluid refuse from the houses, without the addition of any but a small proportion of the rainfall. In flushing the sewers from which the rainfall is so largely excluded, the flushing chambers might receive the first rush of storm water, carrying with it the foul surface washings.

By bringing the volume of sewage to a more uniform flow, the arrangements for purifying it can be more easily carried out, whether by land filtration or by chemical treatment in tanks.

A second sewer is sometimes employed to carry off the rainfall independently of the refuse. Where there are two sewers, special care has to be taken to prevent confusion arising between them, as workmen in connecting a house-drain with the sewerage system might resort to whichever sewer happened to be the nearest. The second or clean sewer might advantageously be employed to lower the level of the subsoil water. Experience has proved the advantage to health that results from the subsoil being drained to a sufficient depth to preserve in a dry state the basements and surroundings of houses.

Sometimes the foul sewers are laid open-jointed in order that they may serve as drains for the subsoil as well as sewage carriers. This endeavour to combine two essentially distinct operations is wrong in principle. The sewer itself should be made absolutely water-tight, so as to prevent the escape of sewage from it into the subsoil.

## CHAPTER IV.

## RIVERS POLLUTION.

THE streams and rivers of Great Britain are likely to remain polluted unless the efforts of the legislature to effect their purification are better enforced, or unless the Acts of Parliament bearing on the subject are so amended as to be made capable of being carried into effect by the sanitary authorities upon whom is imposed the duty of administering them.

The great fault in sanitary legislation is that it is either permissive in its character instead of compulsory, or where it is compulsory it is, through inherent defects, unable to be enforced. The Public Health Act of 1875 states that nothing in the Act shall authorize any local authority to make or use any sewer, drain, or outfall for the purpose of conveying sewage or filthy water into any natural stream or watercourse, or into any canal, pond, or lake until such sewage or filthy water is freed from all excrementitious or other foul or noxious matter such as would affect or deteriorate the purity and quality of the water in them. It is clear that this provision is of no avail, inasmuch as the Act does not prevent, but simply does not authorize.

The Rivers Pollution Prevention Act of 1876, which came into operation in August 1877, prohibits the passage of sewage into streams, and enacts that it shall be an offence to continue the pollution. It states that, "in determining whether or not such an offence has been committed, it should be noted that a marked distinction is drawn between the cases in which the sewage is conveyed into the stream along channels, the construction of which had not been commenced

at the time of the passing of the Act, and those in which it is so conveyed along channels then already existing or in process of construction. In the former case, it will be an offence against the Act for any sanitary authority to cause or permit the discharge into any stream of any solid or liquid sewage matter. In the latter, an offence will not be deemed to have been committed if it can be shown to the satisfaction of the court having cognizance of the case that the *best practicable and available means* are used to render the sewage harmless." The words in italics involve difficulties which have caused the Act to be practically inoperative.

The Act contemplated certificates being given to towns to the effect that they were dealing with their sewage efficiently, but a strict compliance with this appears to be construed into its being necessary to deal with the sewage on land, so that those towns which are so situated as to be unable to dispose of their sewage on land have no means of obtaining the certificate.

It is desirable to have a reasonable definition of what will be considered admissible under the varying circumstances of towns, so as to enable the Act to be administered without the friction which is experienced. To arrive at an authoritative definition requires an intelligent grasp of the whole subject, and as it would be difficult to frame clauses in an Act which would be operative under all conditions, considerable latitude ought to be given to meet the circumstances that arise in practice.

There is no necessity to insist on the high standard of purity for the effluent water proceeding from either irrigation or precipitation such as was fixed on by the Rivers Pollution Commissioners. This was, so far as regards sewage pollution, that the fluid should not contain more than 0·3 parts by weight of organic nitrogen in solution in 100,000 parts by weight. It would be unnecessary to obtain as high a

degree of purity in an effluent discharging into rivers such as the Clyde, the Thames below London Bridge, the Irwell at Manchester, as into a small trout stream. The degree of purity required should depend entirely upon the circumstances of each case.

Whilst referring to the Rivers Pollution Prevention Act, attention may be called to the exemption which was made in it with regard to the metropolitan sewage and the River Thames.

The Metropolitan Board of Works was created in 1855 for the purpose of sewerage London and of purifying the Thames. This duty was imposed on the Board at its formation, and it has fulfilled it to the extent of executing an admirable system of sewerage, with outfalls into the Thames at Barking and Crossness. These are supposed to remove the sewage to where it no longer pollutes the river or the metropolis, but it is generally considered that a large portion of the sewage oscillates to and fro, and so returns to pollute the river within the metropolitan area, and that the Board of Works has only partially accomplished the task for which it was specially created. In Clause III. of the Metropolis Local Management Act Amendment of 1858, it expressly states that the power conferred by the original Act of 1855 shall "extend and be applicable as well to works for *deodorizing* sewage." This clearly indicates that at that time it was contemplated to apply some treatment to the sewage at the outfall, before its discharge into the river.

The Conservators of the River Thames are supposed to have statutory powers to prevent the Metropolitan Board from causing or continuing this pollution, but the powers of the Conservators as regards pollution appear from their Act of 1867 to be confined to the preservation of the purity of the river to the western boundary of the metropolis, so that it may be necessary to establish the fact of the sewage



passing from the outfalls westward before steps can be taken to diminish the evil.

The Conservators have taken action with respect to the outfalls under the 20th and 21st sections of the Thames Conservancy Act of 1870, on the ground that they have injuriously affected the navigable channel by the formation of mud banks. These sections of the Act provide that any banks or other obstruction to navigation which resulted from the discharge of London sewage into the river must be rectified at the expense of the Metropolitan Board. This part of the case is now being dealt with by arbitration, and the award of the umpire will be made in the form of a report to the Board of Trade.

It will be noticed that the sanitary aspect of the question is not gone into, the present inquiry being limited to what may be termed the commercial part of the subject, which has reference to ascertaining whether the Board of Works or the Conservators are to bear the cost of dredging certain mud banks. The result of this arbitration will doubtless influence the sanitary part of the case, but it would have been more satisfactory had the consideration of the matter as it bears on the public health been regarded as of equal importance to the consideration of an interference with the river bed.

Of all the projected means of disposing of the sewage of the metropolis at the outfalls, that which is least likely to be attempted is its application to land. To enable the sewage discharged into the Thames at Crossness and Barking to be utilized on land, an expense would have to be incurred in the acquisition of the enormous acreage required, as well as in pumping the sewage to a sufficient height to control this area, out of all proportion to the commercial results which are likely to be realized. No possible return can be expected from crops produced on metropolitan sewage farms

to cover more than a fractional part of the cost of purifying the sewage on them. The sanitary requirements of the case will be fulfilled by applying inexpensive chemicals to act as deodorants and precipitants, whilst avoiding an unnecessarily high standard of purity. This can be accomplished for about 7*d.* per head of population.

The pressure brought to bear by the Conservators of the River Thames on the various sanitary authorities has resulted in the practical diversion from the river of the sewage of all the towns above the intakes of the Water Companies, except Oxford, but works are in progress to effect the diversion of the sewage of this town.

The authorities of Glasgow have done good service by the independent inquiries they have instituted as to sewage disposal, with the view of effecting the purification of the Clyde.

Abundant information is now available to enable a town to adopt a system which is the best suited to its requirements, and of avoiding the unnecessary expense which many towns have incurred by adopting an unsuitable method of sewage disposal. It can be no longer alleged that there exist reasons why any town, however situated, should continue to cause river pollution.

## CHAPTER V.

## FILTRATION.

IN many places efforts have been made to remove the impurities from crude sewage by artificial filters, or strainers formed of various materials, such as straw, burnt clay, charcoal, coke, ashes, sand, gravel, broken stone, &c.

The glutinous character of sludge invariably clogs the filtering material, which then ceases to be operative, and a nuisance is created by the accumulation and decomposition of the foul matter in the filter. The difficulty in disposing of the offensive solids thus collected, together with the cost of constantly cleansing and renewing the filtering material, has led to this system being regarded as impracticable except on a comparatively small scale and under favourable circumstances.

Some interesting experiments were made by Mr. George Higgin (recorded in the 'Proceedings of the Institution of Civil Engineers,' vol. lvii.), for the purpose of removing the suspended matter from the water of the River Plate, and these apply to a certain extent to the filtration of sewage water. He described the water in its best condition as dirty-looking and yellowish. Left in a stoppered bottle for months together in perfect repose, it never became clear, always remaining yellowish and opalescent. The matter in suspension appeared to be finely comminuted clay, almost in a colloid or gluey form, and incapable of mechanical precipitation in any reasonable time. Only by the addition of alum, or one of the persalts of iron, did it seem possible to effect a precipitation of it. The finest filter paper, even in double or triple folds, was powerless to separate the im-

purity. The result of many experiments led to his arranging a filter which appeared to act efficiently. It consisted in placing finely pulverized cinders between a layer of coarse sand at the top and fine gravel at the bottom, each layer being a foot thick; and even this could have been reduced. The efficiency of the filter appeared to be entirely governed by the interposition of the layer of cinders, the absence of even the fine dust in the cinders diminishing the effect of the filter. To obtain a perfectly brilliant water it was necessary to pound the cinders very fine, and not to separate the dust. From these observations it appeared that an efficient filter could be made in the following manner:—

1st layer. 6 inches of fine sand at top.

2nd layer. 6 inches of finely pounded cinders, including the dust.

3rd layer. 6 inches of fine sand.

4th layer. 2 inches of coarse sand.

5th layer. 6 inches of fine clear gravel at bottom.

The delivery from a filter such as this would probably be about 3000 gallons per square yard per day, with a head of 12 inches.

These observations have reference to the filtration of foul water, or of a fluid such as the effluent from precipitation works, or to dilute sewage. In constructing filters for waterworks one square yard of filter of the following construction is usually allowed for each 700 gallons a day:—

1st layer. 2 feet 6 inches of fine sand at top.

2nd layer. 6 inches of coarse sand.

3rd layer. 6 inches of shells.

4th layer. 2 feet 6 inches of gravel at bottom.

## CHAPTER VI.

## IRRIGATION.

THE progress that has been made in the study of agricultural chemistry of late years has helped to solve many of the problems involved in the application of sewage to land. The published data, which have reference to the properties of the various soils to decompose sewage (at the same time effecting its purification) and to utilize the ammonia and other fertilizing ingredients for the nourishment of plants, are of especial interest

Dr. Voelcker, Dr. Frankland, Professor Way, and other eminent chemists, have done good service in this direction, and their investigations on the subject of the combinations and changes which occur by the application of artificial manures to different soils, and of sewage to land, deserve the most careful study by those who have to advise in regard to sewage disposal.

The following practical conclusions of Dr. Voelcker respecting the absorption by various soils of ammonia (the most valuable fertilizing constituent of sewage) and its salts may be advantageously quoted from the 'Journal of the Royal Agricultural Society,' No. XXVIII., p. 544:—

“ 1. All soils experimented upon had the power of absorbing ammonia from its solution in water.

“ 2. Ammonia is never completely removed from its solution, however weak it may be. On passing a solution of ammonia, whether weak or strong, through any kind of soil, a certain quantity of ammonia invariably passes through. No soil has the power of fixing completely the ammonia with which it is brought into contact.

" 3. The absolute quantity of ammonia which is absorbed by a soil is larger when a stronger solution of ammonia is passed through it ; but relatively weaker solutions are more thoroughly exhausted than stronger ones.

" 4. A soil which has absorbed as much ammonia as it will from a weak solution, takes up a fresh quantity of ammonia when it is brought into contact with a stronger solution.

" 5. In passing solutions of salts of ammonia through soils the ammonia alone is absorbed, and the acids pass through, generally in combination with lime, or, when lime is deficient in the soil, in combination with magnesia or other mineral bases.

" 6. Soils absorb more ammonia from stronger than from weaker solutions of sulphate of ammonia, as of other ammonia-salts.

" 7. In no instance is the ammonia absorbed by soils from solutions of free ammonia, or from salts of ammonia, so completely or permanently fixed as to prevent water from washing out appreciable quantities of ammonia.

" 8. The proportion of ammonia which is removed in the several washings is small in proportion to that retained by the soil.

" 9. The power of soils to absorb ammonia from solutions of free or combined ammonia is thus greater than the power of water to re-dissolve it."

Thoroughly drained land has the property of converting the nitrogenous organic matters in sewage into nitrates. These, however, are not stored up in the soil for utilization when required ; but such as are not quickly absorbed by vegetation pass through the ground beyond the reach of the plant roots. In other words, the fertility of land is not increased by applying larger volumes of sewage than the growing crops on it can assimilate. This has been shown in the case of the well-known Craigentenny sewaged

meadows near Edinburgh, which were (and remain) composed of poor, sandy land. Analyses of the soil, after many years of continuous irrigation with large volumes of sewage, prove that it now contains only about  $1\frac{1}{2}$  per cent. of organic matter, and this is due solely to root fibres. These meadows, therefore, instead of having become converted into rich agricultural land, still remain as they originally were, composed of about 98 per cent. of pure silica.

A report by Mr. McKie, the City Surveyor of Carlisle, gives some interesting experiments made by Dr. Walker, of that town, on six samples of earth, three being taken from land which had been for years under sewage irrigation, and three from land which had not been irrigated. The following are the average results from these experiments, the samples being taken from one foot to three feet from the surface.

The soil was at the surface of a rich alluvial character, from 6 inches to 2 feet in depth, weighing, *in situ*, 68 lbs. per cubic foot. This rested on a bed of sandy, alluvial soil, from 3 feet 6 inches to 10 feet in depth, a cubic foot of which, *in situ*, weighed 80 lbs., and contained  $34\frac{1}{2}$  per cent. of pure sand.

IRRIGATED SOIL.		NON-IRRIGATED SOIL.	
	Per cent.		Per cent.
Organic matter, humus, &c.	3·4	Organic matter, humus, &c.	3·1
Ammonia .. .. .	·016	Ammonia .. .. .	·013
Organic nitrogen .. .. .	·006	Organic nitrogen .. .. .	·005
Nitrates and nitrites ..	trace	Nitrates and nitrites ..	trace
Phosphates .. .. .	·016	Phosphates .. .. .	·015
Chlorides .. .. .	none	Chlorides .. .. .	none

These observations show that there is, practically, no difference between the composition of the irrigated and non-irrigated soils, the former being very slightly richer in the more insoluble substances contained in sewage; but the characteristic ingredients of sewage, namely, chlorides and nitrates, are conspicuously absent. It is therefore clear

that the nitrogenous matters are either absorbed by vegetation or pass through the soil.

The practical conclusion to be drawn from these and similar experiments is, that however well land may act as a purifier of sewage for sanitary purposes, it can only be relied on to utilize the manurial constituents of the sewage according to the requirements of the crops for the time being assimilating them, and that any excess of the supply of manure over the demand by the crops is not stored up for subsequent use, but is wasted, and passes off in the subsoil drainage either partially or wholly purified, according to the nature of the land, and of its preparation to filter and oxidize the sewage passed through it. Land is not made more fertile by filtering the sewage of a thousand people through an acre, than it is if the sewage of a hundred only is applied.

Loamy, porous soil is the best for sewage irrigation from a sanitary point of view. Where the land is of a stiff, clayey nature, it requires to be broken up and deep drained. In laying the drains, special care is necessary to ensure their protection from the direct passage of the sewage and surface water into them through cracks and open spaces. These are so difficult to prevent, that clay soil is a very undesirable one to employ. There are several instances where great expense has been incurred in the attempt to convert clay land into a farm suitable for sewage purification. Such land should be regarded as unfit for the purpose:

Sewage farming has too frequently been regarded only from its agricultural point of view, whereas it must be treated as a combination of both sanitary and agricultural interests. These two, however, can only be successfully combined where a sufficient area of land is acquired to enable the crops cultivated on it to receive the sewage only when it can be utilized. When this cannot be accomplished, the agricultural part of the matter must be disregarded, and



the filtration and purification of the sewage as a sanitary necessity only kept in view. The attempt to combine the two under these circumstances involves failure.

The reason why sewage farming has been so unduly pressed and advocated is, that in the early days of sewage utilization (before it had been subjected to any accurate scientific scrutiny), those who directed public opinion on the question came to the conclusion that the full chemical value of sewage could be realized by its application to land. The result has been that the supposed pecuniary advantages of applying sewage to land have been regarded as an axiom.

With reference to the sanitary aspect of sewage farming, it has been asserted by some that the health of those living in the immediate neighbourhood is injuriously affected, and it has been stated with equal positiveness that this is an entire fallacy.

It is, however, well recognized by physicians that the poison of several diseases is received through the lungs in a worse form than through the stomach; and there must be times when the sewage carriers, or the films of solid sewage over a large surface, are capable of evolving gases or germs which are likely to pollute the air.

The varying nature of the results derived from irrigation is evidenced by the fact that in one case Dr. Frankland found nearly 70 per cent. of the nitrogen originally in the sewage escaping in the effluent water from the Lodge Farm, Barking, when the sewage was not being properly applied to the land. On the other hand, Colonel Hope states that on his farm at Romford, during a whole year only 10·69 per cent. escaped in the effluent, as the most careful supervision was exercised. Such care, however, cannot be ensured always, and where this is not the case, a nuisance is likely to arise which would render a sewage farm objectionable when near dwellings.

The fear of sewage farming being badly conducted is so great that the opponents of an irrigation scheme have no difficulty in creating a prejudice against them.

Sewage farming has in many cases cost far more than is necessary, owing to the works having been constructed for distributing the sewage over the land of an unnecessarily expensive character. Simple and inexpensive arrangements will suffice, and the necessity for economy in this respect cannot be too strongly insisted on.

If the main channels or carriers are constructed substantially in concrete, the tributary ones can be made by hand or by the plough. Main carriers should have a fall of about 1 in 400 and the distributing or small carriers a fall of about 1 in 300.

Before applying sewage to land, the solid portions should be removed by subsidence in catchment tanks, which should be open, and be placed remote from dwellings. They should be frequently cleansed, and the solids got rid of or dug into the earth, otherwise a serious nuisance will be occasioned.

Italian rye grass is one of the best crops for sewage, as its capacity for absorption is enormous, and it occupies the soil so as to choke down weeds, which are a source of trouble and expense on sewaged land. The cultivation of a particular crop must however be adopted with reference to the local markets, so as to prevent the loss of the produce. Many excellent and valuable crops are wasted owing to the consumption in the district being less than the supply.

In the Local Government Board Blue Book, p. xxxiii., it is stated that "no growing crop, save natural grass, should be sewaged during the depth of winter, and for potatoes, turnips, most vegetables, and certainly for all pulse and cereals, the land ought rather to be enriched by frequent irrigation in the preceding season, than treated with sewage when these

crops are growing, except in times of great drought, and even then care is requisite."

Osiers are very useful plants to absorb the organic impurities in sewage. The American water-weed, anacharis, is a very gross feeder, and will assimilate enormous quantities of organic impurity. A small area planted with a little of this weed will soon become an excellent purifier of sewage.

There are other plants which are capable of absorbing organic impurities, such as duckweed, sedges, common reed, flowering rush, white and yellow lilies, frogbit, water ranunculus, liverwort, and watercress.

The fertilizing value of sewage, on which so many erroneous expectations have been based, has been proved to be seriously reduced to the sewage farmer by the fact that for sanitary purposes sewage must be disposed of day by day throughout the entire year, and that the volume to be disposed of is generally greatest when it is absolutely useless to the land.

The cultivation of sewage land requires more than double the amount of labour, stock, &c., that is necessary for ordinary farming.

The Local Government Board Blue Book states that "the continuous application of town sewage to all soils is by no means an unalloyed benefit, as in some cases and seasons, and especially upon clay land, it may be rather injurious than otherwise."

It is desirable to apply sewage to green crops, or root crops proper, and to avoid plants which must flower or fructify before being gathered.

In twenty-two towns referred to in the Table in the Appendix the average cost of irrigation is 6*l.* 10*s.* 2½*d.* per million gallons, or 1*s.* 10¾*d.* per head, or 6*d.* in the £ per annum. The average amount of land employed in these

cases being an acre to 111 people, and the average flow per head of population per diem being 39 gallons.

The difficulties attending the employment of too small an area of land for sewage purification purposes are experienced by a great number of towns where sewage farms have been established, and where the efforts of the sanitary authorities to acquire further land are met either by exorbitant claims or determined opposition on the part of the owners of it.

The mistakes that are made by applying the result obtained at one place, where land and other conditions are favourable, to another place, where these favourable conditions do not exist, may be illustrated by the circumstances attending the disposal of the water-carried portion of the sewage of Paris. A very interesting paper, by Dr. Allen Sturge, was read before the Institution of Surveyors in 1879 on this subject, from which it appeared that about 70 per cent. of all the houses in Paris are provided with large cesspools, and even where this system is not adopted, the solid excrement is not allowed to enter the sewers. It follows therefore that the refuse conveyed by the sewers of Paris is wanting in the organic constituents which govern the arrangements in regard to its purification.

The composition of the sewage of Paris was given by Mr. Target, in a paper which was read at the Institution of Civil Engineers, as being 8700 grains of organic matter and 18,920 grains of inorganic matter per cubic yard. The mean of analyses of sewage by Letheby, Hoffman, Witt, Way, and Voelcker, as given on page 7, yielded 27.72 grains of organic matter per gallon, which is equivalent to 4667 grains per cubic yard. The mean analyses of London sewage (where the houses are all connected) was determined by Hoffman and Witt as yielding 30.7 grains of organic matter per gallon, which is equivalent to 5168 grains per

cubic yard. It is clear that the above analyses of Paris sewage must refer to exceptional samples.

Several analyses of sewage from the Collecteur d'Asnières gave, according to Mr. Target, the following as the composition of one cubic yard:—

Organic matter, including .07 lb. of nitrogen .. ..	lbs. 1.24
Mineral or inorganic matter, including .03 lb. of phosphoric acid .. .. .	} 2.70
	3.94

This is equivalent to 56.5 grains per gallon of organic matter and 123 grains per gallon of inorganic matter.

The water-carried sewage or the "dirty water" of Paris (as Dr. Voelcker has properly termed it), to the extent of 10,000,000 gallons a day (the whole sewage of Paris amounts to 60,000,000 gallons a day), is pumped on to 914 acres of land at Gennevilliers, which is of a character exceedingly suitable for the filtration of sewage, inasmuch as it consists of 4 to 5 inches of vegetable soil with about 10 feet of mixed sand and gravel subsoil. The foregoing figures show that the proportion of land to sewage is 91 acres per million gallons, whereas it is shown in the Table in the Appendix, that an average of twenty-two towns in England gives 234 acres per million gallons.

These towns, however, have to deal with sewage proper, containing all the organic impurities which are really the measure of the purifying work the land has to accomplish, so that the data in regard to the disposal of the sewage of Paris must not be relied on as directly applicable to towns in this country.

However satisfactory the agricultural results may be of disposing of this portion of the sewage of Paris (which is about a sixth), objections have been apparently experienced to the Gennevilliers sewage farm. Dr. Sturge says in his paper,

“Great complaints have been made at Gennevilliers by those who are opposed to the irrigation scheme, that the health of the inhabitants is not so good as before its introduction, in consequence of a rise in the level of the subterranean water, which now invades the cellars of their houses.” M. Lefèvre, President of the Société des Géomètres of France, who has had to make valuation surveys of this district for the Civil Courts of Paris, says, “Gennevilliers is a large agricultural village, and at one time had fine prospects of extension. The value of building land had increased to a very large degree, but as soon as the neighbourhood between Gennevilliers and Asnières was seen to be invaded by the muddy and infected waters of Paris this land lost a great part of its value. The soil, however, has acquired a high degree of fertility.” And again, “My personal opinion is, that the dispersion of the sewage outside the great town must be considered as a public misfortune for the localities infected by it.”

The agricultural value of the land, however, has risen since the cultivators of it have had the means of irrigating it. Plots of non-irrigated land realizing 77*l.* per acre, and of irrigated land 90*l.* per acre. It is estimated that the advance in value of the land averages not less than 3*l.* to 3*l.* 10*s.* per acre per annum.

Whatever agricultural advantages may accrue from utilizing sewage on land, the situation of the land requires careful consideration. It must be remote from habitations, otherwise the advantages are outweighed by the disadvantages.

If the neighbourhood of large towns in this country resembled that of Paris less difficulty would be experienced in the utilization of the sewage on land. The great subdivision of property at Gennevilliers, together with the sandy, hungry nature of the soil, creates a demand for liquid manure such as is rarely found in England. The small holders of land near Paris utilize the sewage on 700 acres out of the

914 under irrigation for "culture maréchaire," or market gardening.

Owing to the prejudice on the part of the cultivators against employing the sewage of Paris, it has been necessary to allow them to have the sewage for nothing, and the town has been glad to dispose of it thus.

The agricultural results accruing from the application of the sewage water of Paris to this kind of soil is exhibited in a Report issued by the Société des Agricultures de France, in 1876, as follows:—

On Irrigated Lands, per Acre.	On Lands not Irrigated, per Acre.
Wheat, from 30 to 55 bushels .. .. }	From 38½ to 65 cwt.
Rye (green), from 122 to 210 cwt. .. }	
Grass lands—	
Green Lucerne, from 492 to 923 cwt. .. }	From 84 to 131 cwt.
Rye grass, 1023 cwt. .. .. }	
Mangold wurzel, 892 cwt. .. ..	369 cwt.
Potatoes, from 687 to 797 bushels .. ..	453 bushels.

A further Report, issued by a Commission which was appointed in 1877, gave the following results:—

Cabbages	∴	..	..	28 tons per acre.
Carrots	..	..	..	20 " "
Beetroot	..	..	..	48 " "
Beans	..	..	..	6 " "

The quality of these products, however, has been to some extent questioned, as the potatoes were found at times to be watery and poor in quality.

Mr. William Crookes, F.R.S., in giving evidence before Sir John Hawkshaw, in the Clyde Purification Commission, in 1875, spoke in discouraging terms of the quality of the vegetables produced at Gennevilliers. He stated, from his own observation, that "the vegetables grew with the greatest luxuriance, but there was no firmness about them; for in-

stance, I could thrust my finger right into the heart of a cabbage with the greatest ease, and if I took a vegetable, a cabbage, or something of that sort, and broke it and squeezed the juice out, I could always detect a sewage smell in the juice. Some quick-growing Italian rye-grass will take up actual sewage into circulation. You can break it and squeeze water out that has a decided smell of sewage."

*Aldershot.*

A recent Official Report of great interest enters into careful comparisons between the results obtained by irrigation at Aldershot and those obtained by chemical treatment at various places.

Aldershot has a population of 11,615, and the sewage is applied to  $2\frac{1}{2}$  acres of land of a porous nature two days out of the seven.

The compositions of the sewage and effluents are given in detail in the Table in the Appendix, but the following show the sanitary results:—

OFFICIAL ANALYSES OF ALDERSHOT SEWAGE AND EFFLUENT FROM IRRIGATION, EXPRESSED IN PARTS PER 100,000.

Description.	Free Ammonia.	Albuminoid Ammonia.	Chlorine.
<i>Wet weather—</i>			
Crude sewage .. .. .	3·660	1·750	4·38
Effluent .. .. .	0·920	0·276	4·54
" .. .. .	0·880	0·200	3·14
" .. .. .	0·440	0·144	3·20
<i>Dry weather—</i>			
Crude sewage .. .. .	12·00	5·25	12·08
Effluent .. .. .	0·245	0·055	15·53



## CHAPTER VII.

## INTERMITTENT DOWNWARD FILTRATION.

A SMALL area of porous land, deep drained and specially prepared, is capable of purifying a larger volume of sewage than land laid out for broad irrigation only. This concentration of a large volume of sewage on a small area of land has been termed "Intermittent Downward Filtration."

There does not appear to be any reason for employing such a term, as ordinary irrigation consists, if properly carried out, in applying sewage intermittently to land for the purpose of its downward filtration through it.

As the difficulty of obtaining land for sewage farming became recognized attention was directed to the possibility of escaping from the necessity of employing more than a small area of land, so as to reduce the difficulty to a minimum.

The laboratory experiments of Dr. Frankland seemed to point to the practicability of this being done on a large scale. He made a series of experiments, 1st, as to the best material to be used as a filtering medium; 2nd, as to the amount of sewage which could be effectually purified per cubic yard of material; and 3rd, as to the best mode of conducting the filtration. His experiments were made with various earths, and the bulk operated on was small; glass tubes, 16 feet long and 2 inches internal diameter, and glass cylinders 6 feet long and 1 foot in diameter, being the appliances employed.

It will be apparent that experiments made with earths in this way will give results better than where the land is *in situ*, and undisturbed, as allowance must be made for the

effect of the solid constituents of sewage filling up the pores in the earth. Until these pores are filled, the percolation through the medium will be much more rapid than it would be in nature. The theoretical result was, that it seemed possible to filter and purify the sewage of 3300 people on an acre of land, provided it were specially prepared and of suitably porous character.

These anticipations have not been realized in practice, but the experiments of Dr. Frankland have been useful in indicating the points which have to be kept in view to obtain efficient filtration. He showed the necessity for the filtering area being allowed from six to twelve hours' rest between each application of the sewage for aëration, and that this alternation will not suffice if the effluent water does not flow freely off from the bottom of the filter. When this takes place, atmospheric air follows the last part of each dose of sewage as it sinks through the filtering material, and so oxidizes the organic matter retained in its pores.

Although in practice, land, however carefully laid out and drained, cannot be worked continually to accomplish anything approaching 3300 people to the acre, yet by proper arrangements it can be made to do far more than ordinary irrigation can accomplish, which is about a hundred people to the acre. At present there are not any practical data to determine what greater quantity of sewage can be applied to land thus prepared.

Intermittent downward filtration should not be spoken of as a system of itself, but simply as a special arrangement of a small area of land to serve as an auxiliary to broad irrigation or to precipitation.

Drainage will not enable land to get rid of the water falling on its surface during periods of continuous rain sufficiently fast to admit of the land acting as a filter to purify large volumes of sewage in addition to the rainfall.

The deodorizing properties of land are, in rainy seasons, neutralized by the presence of the water, which fills all the interstices, and prevents the surfaces and pores of the earth from operating except to a trifling extent.

From a sanitary point of view, land deeply drained and specially prepared, serves to purify larger volumes of sewage than land not so prepared, but no agricultural results should be relied on such as are afforded by broad irrigation.

The Rivers Pollution Commissioners, in their first Report, refer to intermittent downward filtration in the following terms:—

“1. It is entirely unremunerative, the amount of sewage applied to a given area of land being probably in such a case too great to permit of the growth of any ordinary agricultural crop.

“2. The whole of the manure ingredients of the sewage would be absolutely wasted.

“3. The collection of solid fæcal matters upon the surface of the soil, with no vegetation to make use of them, would probably give rise to a formidable nuisance, especially in hot weather.”

## CHAPTER VIII.

## CHEMICAL TREATMENT.

CHEMICAL treatment or precipitation of sewage, if efficiently conducted, enables the solid and a large part of the dissolved impurities in sewage to be removed, and an effluent water produced which could be passed into large rivers or where the highest degree of purity is not required. The remainder of the impurities which chemical treatment cannot remove, may be readily abstracted by passing the effluent from the precipitating tanks through a very small area of land serving as a filter.

The purification of sewage by chemicals has been the subject of much misapprehension, owing partly to the extravagant advantages which have been claimed for the system by its advocates, and partly to the equally unreasonable disparagement to which it has been subjected. By a skilful combination of the best chemical systems with filtration of the effluent through land, many towns which cannot get land sufficient for broad irrigation, can deal with their sewage at a moderate cost, and can produce an effluent water quite capable of complying with a high standard of purity.

Mr. R. Rawlinson, C.B., the chief engineering adviser of the Local Government Board, stated at the Society of Arts Conference, 1879, that "it would be most monstrous if the Government made a hard and fast rule and declared that in all cases, land and broad irrigation alone should be used;" and again, "they had arrived at this point, that with regard to dealing with sewage it was absolutely impossible for scores of towns to acquire the land necessary to purify it by broad irrigation."

The mistaken view is frequently held, that precipitation is only capable of removing the suspended matters and not any of the dissolved organic impurities. This is the case where the inferior precipitants only are used, but where sulphate of alumina is employed, dissolved impurities are also removed. This is shown to be the case in dyeing operations (where mordants are concerned) as well as in the production of lake colour where the property of alum to precipitate organic bodies from their solutions is depended upon.

The inferiority of lime to sulphate of alumina as a precipitant, is evidenced by the fact that at Bradford where the lime process is admirably worked, the effluent contains 4 parts per million of albuminoid ammonia, and at Birmingham 6.6 parts per million of albuminoid ammonia, and at Burnley 3 parts per million. The two latter cases are shown in the Table in the Appendix. At Aylesbury, the effluent from the native guano process (which is based on sulphate of alumina as a precipitant) contained the smaller proportions of 1.57 and 2.60 on two occasions, and the effluent from the third settling tank is shown by the Table in the Appendix to give as low as 0.7 of albuminoid ammonia per million parts, the crude sewage from which this good result was obtained containing 6.60 of albuminoid ammonia per million.

Sewage when fresh causes no nuisance, but after about twenty-four hours, according to the weather, decomposition sets in and it becomes putrefactive, producing deleterious gases. If sewage is dealt with before putrefaction sets in, as is possible by efficient chemical treatment, it is deprived of its capacity for mischief or power to create a nuisance, as it is defecated and rendered inodorous as soon as it leaves the sewers.

Most of the published information about precipitation has been written from one stand point, to advocate some special

system, rather than to afford data to enable a comparison to be made between systems.

The data as regards precipitation which are given in the Local Government Board Blue Book of 1876, were collected at a time when chemical treatment was in a transition state, and the facts contained in it might advantageously be studied in conjunction with those recently obtained for the Department by Dr. Angus Smith.

In order to enable reliable deductions to be made regarding the cost and efficiency of precipitating systems, it is necessary that certain main principles should be laid down at the outset to serve as a basis on which comparisons can be founded. For instance, the quality of sewage and the number of the population connected with the sewers, as well as the flow per head, should be kept in view. The cost of the chemicals should be considered, both with reference to the quality of sewage operated upon, and also with reference to the standard of purity of the effluent produced. The bulk and value of the resultant sludge also must not be overlooked.

In making analyses of effluent waters from precipitation processes, a note should be made as to the qualities of the sewage from which they are derived. For instance, the time of day at which the sample examined is taken should be recorded, the amount of dilution of the sewage by subsoil water noted, the presence or absence of manufacturing refuse, and the extent to which water-closets are employed should be observed, all these being factors. All practical purposes will be served if what are termed sanitary analyses only are made. These show the amounts of chlorine and of free and albuminoid ammonia, the latter being a sufficient guide as to the sanitary condition of the water.

The amount of chlorine contained in an effluent water may be generally taken as a guide to the strength of the sewage operated upon.

The varying methods adopted by chemists of describing analyses is very inconvenient, and it is desirable for them to adopt a uniform system by which analyses can be compared with each other. In many analyses it is necessary to convert parts per 100,000 into grains per gallon. It is a simple arithmetical calculation to convert parts per 100,000 into grains per gallon (namely, multiply by seven and remove the decimal point one figure to the left), but this can be avoided if chemists would adopt a uniform system.

Dr. Voelcker, F.R.S., in the 'Journal of the Royal Agricultural Society of England,' No. XXVIII., states "What is to be done with the sewage in localities where clay soils abound or the land is so situated as to render irrigation impracticable? In such a case the best plan would appear to be to purify raw sewage by means of chemical precipitating agents sufficiently to admit of the clarified and partially purified effluent being poured into a watercourse without creating a nuisance. Numerous experiments with all kinds of precipitating agents, and the experience of others on a large scale, have led me to the conclusion that by far the most efficacious, and on the whole the most economical precipitating agent is crude sulphate of alumina, assisted by the addition of just enough lime to render the effluent slightly alkaline, and to effect the complete precipitation of the alumina from the crude sulphate."

During the last year or two considerable advances have been made in increasing the efficiency and simplifying the working of chemical treatment of sewage, and these results have done much to remove the previous difficulties which attended precipitation.

Sulphate of alumina, sulphate of iron, and perchloride of iron have long been known as disinfectants and purifiers of sewage. The disinfecting properties of a salt of iron were brought prominently forward in 1859 in Dr. Frankland's

Report to the Metropolitan Board of Works in reference to the various schemes then under consideration for deodorizing the sewage at the outfalls. He stated that after examining all the processes only one appeared to satisfy the necessary conditions, and that system was "Dale's Muriate of Iron," which was essentially a concentrated solution of perchloride of iron. Dr. Frankland compared the action of lime and chloride of lime and perchloride of iron, and showed that, both for immediate action and permanency of effect, the iron exhibited markedly superior results. He ascertained by experiments in a tank holding 7500 gallons, that this quantity was immediately deodorized by either of the following agents:—

	Proportion.	Cost per 1,000,000 Gallons.
Perchloride of iron .. .. .	$\frac{1}{3}$ gallon	£ s. d. 1 13 3
Chloride of lime .. .. .	3 lbs.	2 2 10 $\frac{1}{2}$
Lime .. .. .	1 bushel	3 6 6

Careful trials were made as to the permanency of the effect, and with this result, that whereas the sewage to which lime alone was added soon became offensive, that to which the iron had been applied remained free from smell even after the lapse of nine days. Another important element in favour of the iron, was found to be the decided advantage it exhibited over the others as regards the time required for clarification after the addition of the chemicals to the sewage.

Some experiments made by us in 1877 with protosulphate of iron led to a similar result, as it was found to increase the precipitating efficiency of those sulphates of alumina which are nearly devoid of a salt of iron. Our observations resulted in a patent being taken out for the employment of this combination, but we gave up our interest in this patent, con-



sidering it undesirable that those who have to advise as to sewage disposal should have any interest in a particular system.

Mr. Dover in 1851, Mr. Herepath in 1853, and Professor Way more recently, have employed salts of iron to purify sewage, these systems being efficacious, and not the subject of patents now.

In all these combinations the practical objects to be accomplished should be: 1. To obtain with cheap chemicals a fairly good effluent, relying on filtration through a small area of land to complete the work of purification; 2. To effect this with the production of the minimum amount of sludge.

Some of the sulphates of alumina which are sold for sewage treatment, contain iron, and produce very good results.

The proportions in which the sulphates of alumina, salts of iron, or other chemicals should be employed, have never yet been made the subject of proper chemical investigation so as to enable accurate conclusions to be drawn as to which is most efficacious.

Those towns which are situated near the coal-fields can utilize the shale derived from the coal workings, and by applying acid to it a cheap sulphate of alumina can be made.

The results derived from the application of chemicals to sewage, depend a great deal on the construction of the tanks in which precipitation takes place. Where they are shallow and the velocity of the sewage through them is great, the suspended particles, although heavier than the fluid in which they float, are unable to sink by gravitation, but remain suspended long enough to be carried through the tanks by eddies and upward currents. Many precipitation works now in operation have this defect.

An error that is frequently fallen into, is that of applying

the cost of treatment of small volumes of sewage to large ones. Dr. Frankland and Dr. Hoffman, in their Report to the Metropolitan Board of Works on the deodorization of the sewage of London by chemicals, state: "We beg to express our opinion, based upon the experience acquired during this investigation, that the disinfection of vast volumes of sewage can be more easily accomplished than is generally believed, and than we ourselves anticipated at the commencement of our inquiry."

## CHAPTER IX.

## LIME PROCESS.

LIME being a cheaper precipitant than sulphate of alumina and other chemicals, it is thought by some that its use necessarily produces economic results. This is, however, not the case, as any saving in the purchase of the cheaper precipitant is more than counterbalanced in dealing with the large volume of valueless sludge which it produces, and which is composed principally of carbonate of lime and non-nitrogenous organic matter. Sewage is only so partially purified by lime, that it cannot be regarded as "the best practicable and available means" required by the Rivers Pollution Prevention Act. In the recent Official Report already referred to, the sanitary results of lime treatment at Birmingham and Burnley are described as not being equal to the results obtained at Aylesbury and Coventry.

An objection to the use of lime arises where the effluent passes into a river containing fish, as free lime is most injurious to fish. Where it is used under these circumstances great care must be taken that free lime does not escape.

The effect of the addition of lime to sewage was carefully observed many years ago by the leading chemists, and it was found by Dr. Letheby that the dissolved impurities were reduced from 70 to 67 grains per gallon, and the suspended matters from 19 to 1.7. Further experiments on London sewage showed that with 12 grains of lime per gallon, and with an average of many samples of sewage containing 15.0 grains per gallon of dissolved organic impurity, 4.20

only were removed, and of 94·0 grains per gallon of suspended and dissolved organic and mineral impurities 54 grains only were removed.

Dr. Frankland has investigated the effects of treating the sewage of Leicester with lime, and gives the following as the results :—

## ANALYSES EXPRESSED IN PARTS PER 100,000.

Description.	Total Solid Matters in Solution.	Organic Carbon.	Organic Nitrogen.	Ammonia.	Total combined Nitrogen.	Suspended Matter.		
Leicester sewage	107·3	2·017	·809	2·083	2·524	10·50	11·62	22·12
Leicester sewage after treatment with lime .. )	85·9	1·514	·452	2·552	2·553	12·10	4·70	16·80

The analyses in Dr. Angus Smith's Report relating to Birmingham give the following results expressed in parts per 100,000 :—

Description.	Free Ammonia.	Albuminoid Ammonia.	Chlorine.
Crude sewage .. .. .	2·70	1·05	24·16
Effluent from settling tanks ..	3·22	0·66	15·78
Effluent after irrigation .. ..	1·275	0·21	11·46

Dr. Letheby, in a Report to the Referees appointed by the Metropolitan Board of Works, gave the following practical directions to be observed where the lime process is employed :—

1. The lime should be used in a perfectly caustic state, and in the proportion of not less than 12 grains per gallon of sewage.

2. It should be well slaked with water and got into a finely divided or creamy state.

3. It should be thoroughly mixed with the sewage, and well agitated before it is set aside to deposit.

4. The precipitate should be allowed to settle with the liquid quiet for at least one hour.

5. The deposit should be consolidated and deprived of its water as speedily as possible.

In practice it is found that to enable perfect rest to be given to the combined precipitants and sewage, very large tank accommodation is involved, and to obtain a clear effluent the process has to be worked on the intermittent, and not the continuous system. In hot weather the lime process has to be used still more carefully, as putrefaction sets in rapidly, and makes both the effluent water and the sludge become offensive.

To accomplish even the amount of purification that lime is capable of, lime of a particular quality is required, as will be seen by reference to the analyses in the Appendix.

#### *Lime Process—Bradford.*

This place may be taken as a good example of the lime process now in operation.

The population is about 173,000, covering an area of 7221 acres, giving a density of population of 24 to an acre. The number of water-closets is about 2000, and of dry closets 3000. The flow of sewage is 8 to 8½ million gallons per day, or nearly 50 gallons per head. The sewage is of a manufacturing character, containing much dye refuse.

The Corporation having been compelled by injunction in 1868 to cease polluting the Bradford Beck, works were erected by them at a cost of about 60,000*l.* to enable a company to filter the sewage through peat charcoal. This was a commercial failure, and the Corporation adopted pre-

cipitation by lime. The works were accordingly altered to suit at a further cost of 3600*l.*, part of the original expenditure being thrown away. It should be recorded that the 60,000*l.* referred to includes the outfall sewers from the town to the works, and the diversion of and covering over the Bradford Beck. The cost of the precipitation works alone may be taken at about 40,000*l.*

The solids strained from the sewage before it is treated with lime, find a ready market as garden manure, and realize 2*s.* 6*d.* a load. About 300 tons in a dry state are produced every year.

At the outfall, the sewage is distributed through four culverts before delivery into the precipitating tanks, by which the velocity is checked. There are twenty-two tanks 23 feet by 28 feet, having an average depth of 5 feet, the capacity of each being 18,000 gallons.

The combined sewage and lime are allowed to remain at rest from half an hour to forty minutes. The supernatant water from the tanks passes through a series of thirty-four filter tanks 12 feet by 23 feet, filled with 2 feet of coke. The sludge (about 5 inches in depth) is pumped from the precipitating tanks, into twenty tanks in which it again settles, and the residuum is allowed to dry in the open air.

Numerous experiments have proved that in order to obtain satisfactory results the best lime only must be employed. Analyses of suitable and unsuitable qualities of lime have been made by Dr. Wallace, of Glasgow, and are given in the Appendix.

At Bradford, the sludge is pumped on to a large area of land which requires to be filled up, so that the following figures of the cost of clarifying the sewage of Bradford by lime, must not be considered as covering the total cost of this process at a place where provision had to be made for the removal of the sludge. At Birmingham, where the lime

process is employed, land is continually being acquired for this purpose.

Mr. Alsing gives the cost to the Corporation for the year 1878 as follows:—

Management .. .. .	£ 350
Labour .. .. .	1648
Lime (cost being 13s. a ton at the works) ..	1875
Breeze for filters .. .. .	100
Fuel and miscellaneous .. .. .	348
	<hr/>
	£4321

(The Local Government Board Blue Book gives the cost for the year 1876 to be 6276*l.*)

Allowing 2000*l.* (5 per cent. on 40,000*l.*, the cost of the works), it would appear that the total annual cost is 6300*l.*, exclusive of the disposal of the sludge. (The cost according to the Local Government Board Blue Book would be 8276*l.*)

About 8 tons of lime are used per diem, or at the rate of about 1 ton per million gallons. The greatest care is required in ensuring the perfect disintegration of the lime, which has to be reduced to an almost impalpable powder. If this is not accomplished, and if it is not thoroughly dissolved and mixed with the sewage, the amount of lime required would be greatly increased.

The following analyses relating to Bradford, are given in an interesting Report by Dr. Wallace, of Glasgow, on the methods of disposing of sewage which was prepared for the authorities of that town:—

ANALYSIS OF A SAMPLE OF SEWAGE TAKEN AT A TIME OF DAY  
WHEN IT WAS FOULEST.

	Grains per Gallon.
Ammonia, free or saline .. .. .	9·3
(Equivalent to 133 parts per million.)	
Ammonia albuminoid .. .. .	1·4
(Equivalent to 20 parts per million.)	

## ANALYSIS OF EFFLUENT.

	Grains per Gallon.
Ammonia, free or saline .. .. .	56
(Equivalent to 8.00 parts per million.)	
Ammonia, equal to nitrogen, combined in other forms .. .. .	} 28
(Equivalent to 4 parts per million.)	

*Lime Process—Hille.*

A modification of the lime process is that known as Hille's. In this process lime is the chief precipitant, the patent consisting in the addition of magnesium chloride and tar.

It has been employed at several places, and Tottenham (where it is now in operation) is claimed as a good example of its working as exhibiting its economy.

Tottenham has a population of 30,000, with 5000 water-closets, the daily flow of sewage (which is chiefly domestic) is 1,500,000 gallons.

The sewage works were erected about twenty-three years ago, at a cost of some 11,000*l.*, for treating sewage with lime alone. The effluent water is not filtered, but flows direct from the precipitating tanks into the River Lea. The sludge is run off into shallow stanks.

The cost of chemicals for the year from 17th February, 1876, to 17th February, 1877, was stated in a paper read before the Society of Arts Conference, 1879, to be as follows:—

For 353 cubic yards of lime at 13s. 6d. per cubic yard	£ 238	s. 5
For about 1000 gallons of tar .. .. .	25	0
For chemical salts .. .. .	208	0
	<hr/>	471 5
To this must be added the royalty charged for using the patent.. .. .	} 100	0
	<hr/>	£571 5

The cost of the process at the end of 1877, when the works were inspected by the author, was about the same.



ANALYSES OF EFFLUENTS FROM TANKS AT TOTTENHAM AS  
DISCHARGED INTO RIVER LEA.

Date.	Grains per Gallon.	Parts per Million.	
	Chlorine.	Free Ammonia.	Albuminoid Ammonia.
September 3, 1877 .. ..	..	36·4	2·40
November 7, 1878 .. ..	4·5	40·0	3·50

*Lime Process—Scott.*

General Scott, F.R.S., has patented a method of dealing with the sewage sludge derived from the lime process by burning it into cement.

The Corporation of Burnley, in Lancashire, have adopted this process. The population of Burnley is 40,858. The number of water-closets is 900. The daily flow of sewage varies from 1,000,000 gallons in the driest weather to 1,500,000 gallons in ordinary weather, and it is of a domestic character. An annual subsidy is paid by the Corporation of 6*d.* per head, or not less than 1050*l.*, to Scott's Sewage Company, which undertakes for a term of 12 years to produce the best effluent which can be produced by the lime process, and to deal with the sludge by the patented cement process. The cost of the precipitation works was 12,000*l.*

From an interesting Report prepared for the Corporation by Mr. William Bryan, C.E., the following particulars are given. The sewage on reaching the works has the solids removed in two catchpits having gratings three-quarters of an inch apart at their outlets. It is then mixed with milk of lime, which requires careful supervision, both as bearing on the treatment of the sewage, and in regard to the quality of the cement. An excess of lime above that

required to combine with the suspended matter in the sewage, has to be carefully guarded against.

The combined sewage and lime pass into two tanks (duplicates of each other) 100 feet by 40 feet, subdivided by a party-wall to retain the bulk of the sludge in the first compartment. The limed sewage takes about four hours to pass through the tanks, during which time it deposits its sludge. This, after remaining eight or nine days in filtering tanks, is reduced to 65 per cent. of moisture, and is sampled from day to day to ensure the amount of lime in it giving 60 per cent. of calcium oxide.

The sludge is dried, and finally burnt in kilns (of which there are three, costing about 120*l.* each) similar to those used for burning Portland cement. The resulting clinker is ground up, and produces what is described as an excellent hydraulic lime having the following composition:—

Lime	..	..	..	..	..	..	..	57 per cent.
Silica	..	..	..	..	..	..	..	25 "
Alumina	..	..	..	..	..	..	..	6 "

The cost of drying is 7*s.* per ton. The coke for burning in kilns is 1*s.* 4*d.* per ton. Labour, grinding, and bagging, 15*s.* per ton.

The tensile strength is stated to be about 700 lbs. per 1½ inch square, and the cement, passing through a sieve of 50 meshes to the inch, leaves only 7 per cent. residue.

Mr. Granville Cole, Ph.D., states, in a paper read at the Society of Arts, that the manufacture of Portland cement from sewage is much more precarious than when it is manufactured in the ordinary way from chalk, or limestone, and clay. This arises from the fact that the sewage sludge before being burnt must contain a fixed and large proportion of lime, whereas the sludge deposited in the tanks in the ordinary way contains on an average only 46 to 50 per cent.

of lime, necessitating the addition of more lime to bring it up to the requisite strength for burning into cement. He states that the quantity of sewage coming into the works, varying as it does from hour to hour, involves the most careful watching in order that the requisite quantity of milk of lime may be added, and only after careful experiments can the quantity be determined.

The total expenditure per week for labour and materials in purifying the sewage of Burnley and converting the resultant sludge into cement, is stated to be 35*l.*, and the total cement produced averages 15 tons a week, the value claimed for which is 40*s.* per ton.

The Official Report lately issued, gives the following analyses relating to Burnley, expressed in parts per 100,000:—

Description.	Free Ammonia.	Albuminoid Ammonia.	Chlorine.
Crude sewage .. .. .	1·45	1·20	5·12
Effluent from sewage works	1·33	0·305	5·06

## CHAPTER X.

### COVENTRY PROCESS.

THE population of Coventry is 40,000, having 5000 water-closets, and a daily flow of manufacturing sewage, with much dye, of about  $2\frac{1}{4}$  million gallons.

The system employed is precipitation, supplemented by irrigation, with the effluent water on nine acres of land, drained to an average depth of 4 feet (six acres being drained 6 feet deep). There are four precipitating tanks, each capable of holding 225,000 gallons.

About 5 cwt. of solids, garbage, &c., are extracted daily from the sewage before it passes into the tanks, and are utilized as a manure.

The first chemical process which was used at this place was Dr. Anderson's. It consisted in employing a crude sulphate of alumina, made from sulphuric acid and clay, with milk of lime. This was soon abandoned, and coal shale was substituted for clay to produce the crude sulphate, and was in use until 1878, when a protosulphate of iron was added to a crude sulphate of alumina, procured from alum works. Enough milk of lime is added to make the liquid faintly alkaline.

The Town Council of Coventry lease their sewage works to The Rivers Purification Association, for an annual subsidy of 2200*l.*, and this Company undertakes to carry on all the operations.

The works at Coventry originally cost 12,000*l.*, exclusive of the cost of the fifteen acres of land which they occupy. This sum, however, included a building for making the sulphate, which is not now required, the chemicals being

procured from alum manufacturers. It also included some buildings and machinery for drying the sludge, which are now abandoned. To effect the same results as are at present accomplished, an outlay of 8000*l.* may be taken as a basis for estimating the cost of the works for treating the sewage here.

The proportions of chemicals employed per million gallons are as follows:—

15	cwt.	sulphate of alumina.
2½	„	copperas.
6½	„	lime.

The following is Professor Wanklyn's analysis of the crude sulphate of alumina used at Coventry:—

100 centimetres contained—

<i>First Sample.</i>		Grammes.
Sulphuric acid, SO <sub>3</sub>	.. .. .	3·29
Alumina, AL <sub>2</sub> O <sub>3</sub>	.. .. .	1·22
Protoxide of iron, FeO	.. .. .	0·40
<i>Second Sample.</i>		Grammes.
Sulphuric acid, SO <sub>3</sub>	.. .. .	3·24
Alumina, AL <sub>2</sub> O <sub>3</sub>	.. .. .	1·08
Peroxide of iron, Fe <sub>2</sub> O <sub>3</sub>	.. .. .	0·12
Protoxide of iron, FeO	.. .. .	0·10

The following is Dr Wallace's analysis of the sulphate of alumina used at Coventry:—

Sulphate of alumina	.. .. .	Grammes.	10·75
Sulphate of iron	.. .. .	0·99	
Sulphate of lime	.. .. .	0·75	
Sulphate of magnesia	.. .. .	2·01	
Sulphate of soda	.. .. .	4·97	
Sulphuric acid (free)	.. .. .	2·02	
Water	.. .. .	41·84	
Insoluble matter	.. .. .	37·32	
		<hr/>	
			100·65
Alumina	.. .. .	3·23	

The cost of carrying on the works for the year 1878, including the operations on the irrigation area of 9 acres, was .. .. .	£	1984
To enable the entire cost to be arrived at, interest on 8000 <i>l.</i> must be added, which represents the fair cost of the works now utilized .. ..		400
Rent of land, 15 acres, at 4 <i>l.</i> .. .. .		60
<hr/>		
Annual cost of treating sewage of Coventry by precipitation and filtration .. .. .	£	2444
Less amount realized by the sale of agricultural produce and sludge .. .. .		100
<hr/>		
		£2344
<hr/>		

This is equivalent to about 1*s.* 2*d.* per head of the population per annum, or 2*l.* 16*s.* 5*d.* per million gallons of sewage treated, the cost of chemicals being 5*d.* per head per annum, or 1*l.* 1*s.* per million gallons of manufacturing sewage (which requires about one-third more chemicals than when treating a domestic sewage).

The sludge is disposed of after partial drying by exposure to the air in stanks. Although the sludge is not properly dealt with here, the cost of doing so may be regarded as being covered by what it would realize in the more portable and useful form into which it is capable of being converted.

The sewage of Coventry, analysed by Dr. Swete in 1878, gave the following :—

Grains per Gallon.		Parts per Million.	
Solids.	Chlorine.	Free Ammonia.	Albuminoid Ammonia.
56·0	6·5	16·0	12·2

The recent Official Report contains the following analyses relating to Coventry, expressed in parts per 100,000.—

Description.	Free Ammonia.	Albuminoid Ammonia.	Chlorine.
Crude sewage .. .. .	2·58	1·700	6·85
Effluent from settling tanks } (filtered) .. .. .	2·40	0·245	6·30
Effluent after irrigation (drain } out of order) .. .. .	2·12	0·205	5·73
Effluent after irrigation .. .. .	0·52	0·061	4·99

Effluents from the filter beds, analysed by Professor Wanklyn in 1876 and 1878, gave the following :—

Date.	Chlorine in Grains per Gallon.	Parts per Million.	
		Free Ammonia.	Albuminoid Ammonia.
1876	4·0	13·30	1·35
1878	4·2	18·00	1·00

Nearly the whole of the solids are removed from the sewage during precipitation, and the deposited material amounts to about 25 tons per diem, containing 90 per cent. of moisture. This is equivalent to 9000 tons per annum.

If reduced to a portable form, containing 50 per cent. of moisture, the weight would be reduced to about 1800 tons per annum, in which state it is capable of utilization on land.

An analysis of the Coventry sludge was made by Dr. Voelcker, F.R.S., for the Local Government Board, and is given in the Blue Book. The theoretical value, with 47·36 per cent. of moisture, is stated to be 16*s.* 9½*d.* a ton in comparison with Peruvian guano, and 5*s.* 6*d.* to 8*s.* 4*d.* a ton is

stated to be the market value in comparison with farmyard manure. Dr. Wallace, of Glasgow, has assigned a value of 27s. a ton to this air-dried sludge, with 10 per cent. of moisture.

The Borough Surveyor of Coventry, after using some of the sludge on land, says: "There can be no doubt that the manure is a valuable one, and possesses strong fertilizing properties; and as an evidence of my faith in its value, I shall next winter endeavour to put another heavy dressing on our land.'



## CHAPTER XI.

## THE A B C (OR NATIVE GUANO) PROCESS.

THE precipitants employed are alum, blood, clay, and charcoal.

This process is now in operation at Aylesbury, a town of 7200 inhabitants, of which about 6000 contribute to the flow, one district not being sewered. The ordinary flow is about 300,000 gallons a day of domestic sewage, which is increased in wet weather.

The following are the ingredients employed:—

	Parts by Weight.
A. Crude alum cake, containing 40 per cent. of sulphate of alumina .. .. .	6
B. Blood, about 5 lbs. to 1 ton of clay, or .. .. .	$\frac{1}{48}$
C. Clay containing 25 per cent. of moisture .. .. .	6
Charcoal .. .. .	6

The crude alum cake, containing 40 per cent. of sulphate of alumina, costs at the works 3*l.* 0*s.* 8*d.* per ton (9*s.* 2*d.* per ton being for carriage).

The blood costs 1*s.* per week, and is obtained from local slaughter-houses, and is mixed while fresh with moist clay, dug from a field in the immediate vicinity of the works for about 2*s.* per ton.

The carbon or charcoal is a waste product from prussiate of potash manufactories at Manchester, and is obtained for 1*s.* per ton there; but its carriage to Aylesbury raises its cost to 15*s.* 10*d.* per ton.

The blood, clay, and charcoal, after being ground together in a pug mill, with sufficient water to enable them to flow, form the first ingredients, which are mixed with the sewage. The alum is next added in a dissolved state.

The sewage thus treated flows along a salmon ladder mixer

into brick tanks (of which there are three), 50 feet long, 30 feet wide, 7 feet 3 inches deep at the inlet end, and 5 feet 3 inches at the other. There is a lip 2 feet below the coping, so that the average depth of each tank is 4 feet 3 inches, containing 40,000 gallons. These tanks are worked, as a rule, in pairs, the effluent from one passing to a second for further precipitation before it is discharged into the River Thame, at that point a small stream a few feet in width. The effluent water, on the occasion of two inspections in October 1877, was clear and practically inodorous. Four samples of effluent were taken, of which the following are analyses:—

Samples.	Parts per Million.	
	Free Ammonia.	Albuminoid Ammonia.
Effluent water after passing through one tank, 2.30 P.M., 2nd October, 1877 .. }	45.4	1.50
Ditto, ditto, after passing through two tanks, ditto .. .. . }	37.2	0.90
Effluent water after passing through one tank, 4 P.M., 5th October, 1877 .. }	80.0	2.60
Ditto, ditto, after passing through two tanks, ditto .. .. . }	45.6	2.10

In the recent Official Report, the following analyses are given relating to Aylesbury, expressed in parts per 100,000:—

Description.	Free Ammonia.	Albuminoid Ammonia.	Chlorine.
Crude sewage .. .. .	4.00	0.66	7.97
Effluent from 3rd settling tank ..	1.02	0.07	5.44

The degree of purity of the effluent will be observed to depend on the number of tanks it flows through. It would be difficult in practice to ensure the continuous employment of all three tanks.

The sludge is partially dried by filter presses, and further by artificial heat or exposure to the air, when it is ground into

a powder containing 14 per cent. of moisture, and bagged for sale.

The quantity of sludge, containing 90 per cent. of moisture obtained in twenty-four hours at these works, is 20 tons, equal to 140 tons per week, or 7280 tons per annum, or about 1500 tons, containing 50 per cent. of moisture. This, when dried, produces 845 tons of native guano per annum, containing 14 per cent. of moisture, or rather over  $2\frac{1}{2}$  tons a day.

The daily quantity of ingredients in use for treating the sewage is as follows:—

	tons.	cwt.	qrs.	lbs.
Alum .. . . .	0	6	0	0
Blood .. . . .	0	0	0	5
Clay .. . . .	1	0	0	0
Charcoal .. . . .	0	6	0	0
	<u>1</u>	<u>12</u>	<u>0</u>	<u>5</u>

The weekly cost of treating the sewage at Aylesbury is:—

	Per Week.
Chemicals, 13 tons $2\frac{1}{2}$ cwt., costing .. .. .	£12 13 1
Coal, engines, 7 tons 10 cwt., at 14s. .. .. .	5 5 0
Wages and engineman .. .. .	2 19 6
Wages, A B C .. .. .	2 16 0
Cleaning tanks .. .. .	0 3 7
Oil, tallow, and petty expenses .. .. .	1 15 0
	<u>£25 12 2</u>

Or 1*l.* 12*s.* per ton of native guano.

In addition to this, the cost of drying, &c., is 5*s.* 8*d.* per ton; of grinding, bagging, &c., is 5*l.* 14*s.* 2*d.* for  $7\frac{1}{2}$  tons, or about 15*s.* per ton, so that the total cost of a ton of finished native guano is as follows:—

	Per Ton.
1. Chemicals, labour, &c. .. .. .	£1 12 0
2. Drying, &c. .. .. .	0 5 8
3. Grinding and bagging .. .. .	0 15 0
Total cost per ton .. .. .	<u>£2 12 8</u>

It must be borne in mind that these figures would require modification were the clay not obtained at the point where it is required, as at Aylesbury. If the clay had to be carted from a distance, the extra cost would have to be added, and this might be considerable.

The following is Professor Wanklyn's analysis of a sample of A B C Aylesbury manure, taken fresh from the filter press (and five days from tanks):—

Water	..	..	..	..	..	..	59·05
Organic matter	..	..	..	..	..	..	12·23
Ash	..	..	..	..	..	..	28·72
							100·00

0·07 per cent. free ammonia.

0·02 per cent. albuminoid ammonia.

Dr. Wallace, of Glasgow, calculates the value at 33s. per ton containing 12·60 per cent. of moisture.

The cost of chemicals and labour is 2162*l.* per annum, or about 6s. per head of the population of 7200.

It will be seen that a very large proportion (estimated at 80 per cent.) of this sludge or manure consists of the ingredients added to the sewage.

The addition of clay and charcoal no doubt exercises the influence claimed for them, namely, that the charcoal aids the deodorizing properties of the sulphate of alumina, whilst the clay, in a state of fine subdivision, offers a large surface for the absorption of impurities which are carried down with the precipitate. The addition of the clay increases the bulk of the precipitate, and when the value of the resultant product realizes the value claimed for it, the cost of obtaining the clay and of manipulating the bulky product would be justified. If, however, the value required to be realized to cover the cost of the process be not obtained, there are no sufficient reasons for incurring the expense of these ingre-

dients, because a good effluent can be obtained by sulphate of alumina and lime alone at much less cost.

The value claimed for the manure from this process dried to 14 per cent. of moisture is 3*l.* 10*s.* per ton. This value, however, is not recognized by chemists, but the difference between chemists may be described in the words of Mr. Crookes, F.R.S. (the Chairman of the Company), who stated in the 'Quarterly Journal of Science' for January 1873, "Of the value of a manure, chemistry can tell us little more than it can of the value of water. Just as a mere chemical analysis would utterly condemn water containing Liebig's extract, infusion of tea, or a glass of bitter ale, as largely contaminated with nitrogenous organic matter or albuminoid ammonia, so chemistry, by taking a fictitious standard for manures, and judging only by the percentage of two of the many constituents of the food of plants, gives an arbitrary money value to a manure, which is often exceeded by the price it fetches in the market. Agriculturists frequently pay more for nitrogenous and phosphatic manures than the price assigned to them by chemical analysis, and the sales of native guano form no exception to this rule."

## CHAPTER XII.

## SEWAGE SLUDGE.

THE sludge from raw sewage deposited in catchment tanks, such as are often adopted in either irrigation works, or before discharging the sewage at the outfall into the sea or otherwise, contains an amount of organic matter which is valuable for utilization as a manure on land. The composition of such deposit varies with the nature of the sewage. That from a well water-closeted town is richer than that from a manufacturing town where the refuse is not chiefly human excreta. Dr. Frankland, at the Society of Arts in November 1879, stated that experiments with the sewage of London had led him to the conclusion that after the separation of the detritus the maximum percentage of organic matter was 63, whilst the minimum was 21, the average being  $39\frac{1}{2}$ , and he considers that it would not be safe to calculate on more than 33 per cent. of organic matter in the dried sludge, which would much reduce the value of the manure, for the value of a manure diminished in an accelerated rate as its strength was reduced.

The sludge produced from the precipitation of sewage by chemicals will be more or less valuable according to the chemicals employed. If lime is the only precipitant the resultant sludge is of small value, and the disposal of it is attended with difficulty, both on account of the larger volume produced, and because its feeble manurial properties prevent the possibility of its destination being the fertilization of the land.

If the chief precipitant is sulphate of alumina, the sewage is clarified and precipitated with but a trifling addition of

solid material to that derived from the sewage, and the result is that a sludge is produced having a value as a fertilizer.

There are four methods now practically in use for dealing with sludge. (1) Reducing it by exposure or by presses to a semi-dried condition containing about 50 per cent. of moisture. (2) Drying it to powder by artificial heat to about 15 per cent. of moisture. (3) Fortifying it with materials of a highly fertilizing value. (4) Burning it.

The liquid sludge can be reduced to the consistency of stiff clay (containing about 50 per cent. of moisture) by exposure to the air in thin layers on land drained to receive it. A better method is to employ filter presses, which, if properly constructed, successfully remove sufficient of the water to reduce the sludge to 50 per cent. of moisture at a cost of about 3s. per ton. The fluid sludge is by these presses converted rapidly into the form of cakes, and the drying can be carried still farther if they are left exposed to the air under sheds.

Sewage sludge containing 50 per cent. of moisture is stiff enough to be readily handled, carted, and distributed on land. After it is brought to this state, it is capable of being stored in a comparatively small space without nuisance, and ready for application to land at the proper seasons.

Another system is the fortification of sludge by adding to it a more valuable material to enhance its fertilizing properties, and to ensure its acceptance by agriculturists.

A plan is in operation by Col. Jones, V.C., at Wrexham, by which a manure is produced from the solids removed from sewage in catchment tanks. The sludge is first dried to about 20 per cent. of moisture, and it is then fortified as follows:—

12 parts dried sewage sludge  
7 parts fine raw bone meal.  
1 part sulphate of ammonia.

This it is stated shows on analysis 4 per cent. of ammonia and 20 per cent. of bone phosphate, and it is sold for 6*l.* 10*s.* per ton, which gives a fair profit.

Various chemical values have been assigned to sludge manures owing to the various methods employed in its production. The Native Guano Company claim a value of 3*l.* 10*s.* per ton for their manure when dried to 15 per cent. of moisture, but this is not recognized by chemists. The safest view to take is that a sludge produced from the lime process is valueless and not worth removing to land for utilization, but a sludge from a sulphate of alumina process, which contains the least bulk with the maximum of the manurial ingredients of sewage, is worth carting to a distance like farmyard manure, and further that it can be made portable in the way indicated, and that it will realize a profit of a few shillings a ton when its value is known to the farmers in the districts producing it.

The Table on page 64 is given in Dr. Wallace's Report on Glasgow Sewage in November 1879, and shows very clearly the relative composition of sewage sludge produced by the various precipitating processes. It also confirms the truth of what has been already stated as to the advantage of employing sulphate of alumina as one of the chemicals, inasmuch as the amount of phosphoric acid contained in sludge from systems where this is employed is fully twice as much as it is in sludge produced from the lime process.

Dr. Voelcker has stated, that from a number of experiments which he had made, he found that sewage sludge after it had been thoroughly drained for 48 hours contained over 80 per cent. of water; after three or four days it contained 75½ per cent.; after five days 72 per cent.; and after eight days of rest lost little more.

In estimating the bulk of sewage sludge (and the same applies to mud of any kind), errors are frequently made in



## ANALYSES OF SEWAGE SLUDGE (AIR-DRIED).

Name of Town.	Aylesbury.		Birmingham.		Bolton.		Bradford.		Coventry.		Leeds.		Leicester.		Windsor.	
	A B C.		Lime. 1 2		Lime and Charcoal.		Lime.		Sulphate of Alumina.		Medi- fied. A B C.		Hanson's Process.		Hille's Process.	
Date.	1879.	1879.	1879.	1879.	1879.	1879.	1876.	1879.	1877.	1879.	1876.	1876.	1879.	1879.	1876.	1877.
Water .. .. .	12·60	12·70	13·16	14·34	14·34	8·90	6·92	14·04	10·04	9·56	16·40	11·93	11·76	11·93	16·40	11·76
Organic matter, carbon, &c.	35·60	19·19	20·04	26·18	26·18	33·75	34·53	20·58	23·09	20·82	27·92	22·18	12·06	22·18	27·92	12·06
Phosphoric acid .. .. .	2·11	·40	·72	·62	·62	·80	·73	1·56	2·07	·64	·75	1·21	·87	1·21	·75	·87
Sulphuric acid .. .. .	2·70	1·45	·35	·61	·61	·64	1·74	1·32	·56	2·15	1·02	·51	·49	1·21	1·02	·49
Carbonic acid .. .. .	..	7·62	8·53	8·30	8·30	10·53	13·77	6·64	5·71	8·42	13·11	15·25	22·71	15·25	13·11	22·71
Lime .. .. .	2·18	11·19	12·74	14·50	14·50	16·90	20·27	9·16	6·65	9·68	17·51	20·16	31·09	20·16	17·51	31·09
Magnesia .. .. .	·18	·90	1·37	1·06	1·06	1·66	5·07	·86	·61	5·64	7·67	1·48	1·58	1·48	7·67	1·58
Oxide of iron .. .. .	6·20	2·70	3·20	1·98	1·98	2·11	2·01	4·14	2·66	4·61	2·32	2·66	1·68	2·66	2·32	1·68
Alumina .. .. .	6·75	2·68	2·58	2·97	2·97	3·49	3·89	4·13	5·80	7·04	6·30	1·63	2·31	1·63	6·30	2·31
Sand, &c. .. .. .	33·50	41·13	37·93	29·50	29·50	21·80	10·23	37·83	42·00	31·60	7·36	22·30	14·16	22·30	7·36	14·16
	101·22	99·96	100·62	100·06	100·06	100·58	99·16	100·26	99·19	100·16	100·36	99·31	98·71	99·31	100·36	98·71
Phosphate of lime .. .. .	4·61	·87	1·57	1·35	1·35	1·74	1·59	3·40	4·52	1·39	1·64	2·64	1·90	2·64	1·64	1·90
Nitrogen .. .. .	1·60	·52	·49	·61	·61	·62	·66	·92	1·27	·66	·70	1·08	·52	1·08	·70	·52
Equal to ammonia .. .. .	1·94	·63	·60	·74	·74	·76	·80	1·11	1·55	·80	·84	1·31	·63	1·31	·84	·63
Calculated value per ton	33	10	9	11	13	15	1	20	27	14	17	2	7	21	17	11

calculating the volume and weight of it with the various proportions of moisture.

The bulk of sewage sludge when removed from precipitating tanks and after the supernatant water has been drawn off, may be taken to consist approximately of 90 parts water and 10 parts solids. As the sludge becomes dried, its weight diminishes in a ratio which is frequently misunderstood and which it may be useful to define by the following rule:—

Let

X = weight of sludge to be ascertained.

S = weight of solids in the sludge (which is constant).

P = percentage of moisture in the sludge.

Then

$$X = \frac{S \times 100}{100 - P}.$$

For instance, to ascertain what weight 25 tons of sludge containing 90 per cent. of moisture would be reduced to when it is dried to 15 per cent. of moisture.

Twenty-five tons of sludge with 90 per cent. moisture contain 2·5 tons of solids (which is constant), therefore, applying the formula:—

$$X = \frac{2\cdot5 \times 100}{100 - 15} = 2\cdot94 \text{ tons.}$$

The following Table shows the diminishing weights of 100 tons of sludge with proportions of moisture varying from 90 to 15 per cent.

	Tons.	Per cent.
100 tons with 90 per cent. of moisture ..	= 50	with 80
” ” ” ” ..	= 33·3	” 70
” ” ” ” ..	= 25	” 60
” ” ” ” ..	= 20	” 50
” ” ” ” ..	= 16·6	” 40
” ” ” ” ..	= 14·3	” 30
” ” ” ” ..	= 12·5	” 20
” ” ” ” ..	= 11·76	” 15

## CHAPTER XIII.

## DISCHARGE OF SEWAGE INTO THE SEA.

A VERY general impression prevails that if a town is situated close to the sea it is necessarily in a more advantageous position than inland towns respecting the disposal of sewage, as it has only to avail itself of its proximity to the sea to discharge into it. That this is not a safe assumption the experience of many watering-places proves, and it is therefore desirable to offer a caution to those who are contemplating adopting a similar course.

In the Local Government Board Blue Book of 1876, one of the conclusions arrived at is as follows:—"That towns situate on the sea-coast or on tidal estuaries may be allowed to turn sewage into the sea or estuary below the line of low water, provided no nuisance is caused; and that such mode of getting rid of sewage may be allowed and justified on the score of economy." Also there follows the qualifying expression, "provided no nuisance is caused." It would have been better to have further indicated the conditions which require to be complied with to prevent a nuisance, as it will be found that in a great number, if not the majority, of cases the conditions do not exist. It might have been stated that to avoid a nuisance the sewage must be discharged into the sea at a point not only below low water, but where there is a well-ascertained current which would carry it permanently seaward. A point of discharge complying with these conditions cannot always be found to exist close to the town, or requires to be ascertained by careful tidal and other observations. At the outfall there should be a continuous movement seaward during the twenty-four hours, instead of

an oscillating action to and fro, resulting in a return of the sewage and its deposition along the shore, not only at the outfall and in its immediate neighbourhood, but also at distant places to which the tide carries.

The foreshore of many watering-places is being polluted in this way, and in time it will prejudicially affect them, as the knowledge that the foreshore is polluted becomes generally known. The expenditure necessary to ensure an efficient system of sewage disposal, although it may appear heavy at first, is in the end the truest economy.

The difficulties attending the discharge of sewage into the sea would be diminished were it not that it has a higher temperature and a lower specific gravity than sea or river water, which causes it to rise to the surface. If it is not carried seaward quickly, part of the suspended solid impurities are deposited on the coast wherever there is still water and no tidal current, whilst the rest of the suspended together with the dissolved impurities float on the surface and are carried backwards and forwards by every tide, decomposing and liberating offensive gases.

This action was pointed out by Professor Stanley Jevons, in a letter to the 'Times' of December 2nd, 1878, with reference to the formation of sewage mud banks in the Thames, by the discharge of sewage at the outfalls at Crossness and Barking. He pointed out that matters which would remain suspended for many days in fresh water would be readily precipitated in a few hours when the water is saline, and states that "much of the sewage matter, indeed, would if left to itself float in water, but in the presence of saline matter, which kills the pedetic or oscillating motion of suspended particles, cohesive attraction comes into play. The minute particles of suspended clay will then adhere to the organic sewage particles and carry them to the bottom of the river, where they will form foul pestiferous banks of ooze.

In the same way we may explain the peculiarly unhealthy effect produced at seaside watering-places, where the sewage is poured down the beach into the sea in front of the town (if any such there still be). Unless there be strong tidal currents the foul particles are not carried away, but are precipitated and mingled with the sand and mud of the beach. If the salt water enters the sewers the deposit will occur therein, and we may infer that flushing the sewers with sea-water will probably do a good deal more harm than good."

In the 'Proceedings of the Boston Society of Natural History' for February, 1874, Dr. Hunt states, "I have called attention to the fact that the clay resulting from the decay of rocks remains for many days suspended in pure water, though not in waters even slightly saline, and is therefore readily precipitated in a few hours, when the turbid fresh waters mingle with those of the sea, thus forming fine argillaceous sediments. The geological significance of this fact was, it is believed, first pointed out in 1861, by Mr. Sidell, in Humphrey's and Abbot's 'Report on the Physics and Hydraulics of the Mississippi River' (Appendix A., p. xi.), where he applied it to explain the accumulations of mud at this river's mouth."

Sea-water delays the oxidation of organic matters, so that the foul constituents of sewage, which in river water would be liberated and got rid of in a short time, are preserved in sea-water, which causes them to accumulate and form dangerous deposits ready for the quickening action of the summer sun, when gases injurious to health are evolved.

The objectionable nature of deposits from sewage is evidenced by the observations made by the late Dr. Letheby on the mud banks that are forming in the River Thames. He describes them as being "composed of black and foetid mud in a state of active putrefactive decomposition, and when examined under the microscope they were found to consist

of broken-up sewage matters, the remains of animalcules, the disintegrated tissue of vegetables, and swarms of diatomaceous remains;" and he stated "that the mud and the suspended matters of the river contained from 6·3 to 18·9 per cent. of the solid constituents of sewage. To prevent the possibility of doubt, the connection between the deposits in the river and the sewage discharge from the outfalls has been clearly traced by analyses, and the chemical correspondence between the two unmistakably established."

The same opinion is held by Dr. Frankland and Dr. Tidy as to the similarity in chemical composition between the mud banks in the Thames and the sewage at the outfalls.

In some cases, by means of long outfall sewers, the sewage is carried away from the place producing it to the sea, but they are frequently simply transferring the refuse to others, a set of the tide carrying it so as to cause mischief and nuisance elsewhere.

These outfall sewers require careful ventilation, as the sewer gases are otherwise liable to be forced back into the town drains at high tides, or after storms, and thus into the houses, even if the house drains are trapped from the main sewer.

A catchment pit should be placed at the outfall, and the solids deposited therein removed systematically. Even then the addition of a disinfectant and deodorant is sometimes desirable.

## CHAPTER XIV.

COMPARISON BETWEEN IRRIGATION, CHEMICAL TREATMENT, AND  
THE PRINCIPAL CHEMICAL SYSTEMS.

THE Report, made in October, 1879, by Dr. Angus Smith to the Local Government Board, furnishes some interesting comparisons between the results obtained by passing sewage through land at Aldershot during both wet and dry weather, and those obtained by chemical treatment *per se*, and also when supplemented by filtration through a small area of land. It may be observed that the results at Aldershot are probably the best that could be obtained on land, as at that place the quality of the land is specially adapted to filtration, inasmuch as it is very porous. Further, it is understood from the official "Suggestions," which were issued in 1878, that Aldershot is a place where the sewage is applied to land only two days out of the seven. This is assumed to have been the case at the time the observations were taken to which reference will be made. It is important to record these conditions, as the results are liable to be considerably influenced thereby.

It would have been desirable to have recorded the effect of chemical treatment under circumstances as similar to each other as were possible. For instance, if observations had been made on samples of effluent taken from a single tank to show the effect of the treatment during a similar period of time. The sample taken at Aylesbury after the sewage has passed through three tanks is compared with

those taken at Coventry after the effluent has been filtered through land, the conditions being clearly dissimilar.

Whilst indicating in what respect these observations are defective, with the view of their being remedied in any future ones, they may be regarded as affording useful data at a time when further observations were much needed. It is obvious that a series of experiments of this nature are beyond the powers of a private practitioner to undertake, and those who are interested in the sewage question will appreciate the value of these official experiments.

The results of these experiments are given in the following Tables, which record the analyses of samples of effluent water taken from the sewage farm at Aldershot during dry and wet weather, from Aylesbury (where the A B C Company's process is in use), from Coventry, and also from Birmingham and Burnley (where the lime process is employed).

In order to make these Tables better capable of being understood it is desirable to refer, in the first place, to the quality of the sewage of the various towns referred to. Table No. 1, therefore, is compiled to give this information.

TABLE NO. 1.—SHOWING COMPOSITION OF THE CRUDE SEWAGE  
IN PARTS PER 100,000.

Town.	Free Ammonia.	Albuminoid Ammonia.	Chlorine.
Aldershot (dry weather) .. ..	12·00	5·25	12·08
"   (wet weather) .. ..	3·66	1·750	4·38
Aylesbury .. .. .	4·00	0·66	7·97
Birmingham .. .. .	2·70	1·05	24·16
Burnley .. .. .	1·45	1·20	5·12
Coventry .. .. .	2·58	1·70	6·85

The presence of free ammonia is of no disadvantage on sanitary grounds, although it is useful as a manure when



absorbed by the soil. The next Table shows the amount of free ammonia abstracted.

TABLE NO. 2.—FREE AMMONIA.

Town.	Ammonia abstracted.		Ammonia remaining.	
	Parts per 100,000.	Per Cent. of Total.	Parts per 100,000.	Per Cent. of Total.
Aldershot (b) .. ..	11.775	97.96	0.245	2.04
Coventry .. ..	2.06	79.8	0.520	20.2
Aldershot (a) .. ..	2.913	80.10	0.747	19.9
Aylesbury .. ..	2.980	74.5	1.020	25.5
Birmingham (a) .. ..	1.425	52.9	1.275	47.1
Burnley .. ..	0.120	8.3	1.330	91.7
	added	added		
Birmingham (b) .. ..	0.520	18.8	3.220	118.8

NOTE.—Aldershot (a) specimen collected in wet weather; (b) in dry weather; Birmingham (a) after lime precipitation and irrigation; (b) after lime alone.

The next Table gives the amount of albuminoid ammonia abstracted, which is a measure of the sanitary results obtained.

TABLE NO. 3.—ALBUMINOID AMMONIA.

Town.	Ammonia abstracted.		Ammonia remaining.	
	Parts per 100,000.	Per Cent. of Total.	Parts per 100,000.	Per Cent. of Total.
Aldershot (b) .. ..	5.195	98.95	0.055	1.05
Coventry .. ..	1.639	96.40	0.061	3.60
Aylesbury .. ..	0.59	89.40	0.070	10.60
Aldershot (a) .. ..	1.543	88.2	0.207	11.8
Birmingham (a) .. ..	0.840	80.0	0.210	20.0
Burnley .. ..	0.895	74.6	0.305	25.4
Birmingham (b) .. ..	0.390	37.1	0.660	62.9

The next Table shows the amount of residual ammonia abstracted, which is also a factor in regard to the sanitary results effected.

TABLE NO. 4.—RESIDUAL AMMONIA.

Town.	Ammonia abstracted.		Ammonia remaining.	
	Parts per 100,000.	Per Cent. of Total.	Parts per 100,000.	Per Cent. of Total.
Aldershot (b) .. .. .	11·36	100·0	0·00	0·00
Coventry .. .. .	5·081	99·8	0·009	0·2
Aylesbury .. .. .	4·269	88·0	0·581	12·0
Aldershot (a) .. .. .	3·177	83·0	0·636	17·0
Birmingham (a) .. .. .	3·351	61·4	2·109	38·6
Burnley .. .. .	1·200	29·65	2·503	70·35
Birmingham (b) .. .. .	1·530	28·0	3·930	72·0

The next Tables give the total organic ammonia and the total ammonia.

TABLE NO. 5.—TOTAL ORGANIC AMMONIA (i. e. Albuminoid and Residual).

Town.	Ammonia abstracted.		Ammonia remaining.	
	Parts per 100,000.	Per Cent. of Total.	Parts per 100,000.	Per Cent. of Total.
Aldershot (b) .. .. .	16·555	99·65	0·055	0·35
Coventry .. .. .	6·720	98·97	0·070	1·03
Aylesbury .. .. .	4·859	88·20	0·651	11·80
Aldershot (a) .. .. .	4·720	84·84	0·843	15·16
Birmingham (a) .. .. .	4·191	64·40	2·319	35·60
Burnley .. .. .	2·095	42·73	2·808	57·27
Birmingham (b) .. .. .	1·920	29·60	4·590	70·40

TABLE NO. 6.—TOTAL AMMONIA.

Town.	Ammonia abstracted.		Ammonia remaining.	
	Parts per 100,000.	Per Cent. of Total.	Parts per 100,000.	Per Cent. of Total.
Aldershot (b) .. .. .	28·31	98·9	0·300	1·1
Coventry .. .. .	8·78	93·6	0·590	6·4
Aldershot (a) .. .. .	7·633	82·7	1·590	17·3
Aylesbury .. .. .	7·839	82·4	1·671	17·6
Birmingham (a) .. .. .	5·616	60·9	3·594	39·1
Burnley .. .. .	2·215	34·9	4·138	65·1
Birmingham (b) .. .. .	1·400	15·2	7·810	84·8

The amount of oxidation effected on the organic matter is evidenced by the following Table:—

TABLE NO. 7.—NITRIC ACID.

Town.	Sewage.	Effluent.
Aldershot (b) .. ..	..	9·23
Aylesbury .. ..	None	3·19
Aldershot (a) .. ..	Traces	2·79
Birmingham (b) .. ..	None	2·13
Coventry .. ..	"	1·22
Burnley .. ..	..	1·20
Birmingham (a) .. ..	None	1·19

The tendency of the effluents to putrefy is shown by the following Table, in which it will be seen that the lime effluents changed most:—

TABLE No 8.

Town.	Date.	Free Ammonia.	Albuminoid Ammonia.
Burnley, collected 16th June, 1879 .. ..	June 20, 1879	1·33	0·305
	July 17, "	1·92	0·23
	" 28, "	1·92	0·30
	Sept. 4, "	2·15	0·13
Birmingham, collected 23rd June, 1879 .. ..	June 25, "	3·222	0·662
	July 17, "	4·20	0·336
	" 18, "	4·15	0·336
	" 28, "	3·90	0·324
Aldershot (wet) .. ..	July 7, "	0·44	0·144
	" 28, "	0·364	0·130
Effluent C. .. ..	Sept. 4, "	0·140	0·092
	Sept. 16, "	0·245	0·055
Aldershot (dry) .. ..	Oct. 11, "	0·240	0·058
	July 23, "	0·96	0·067
	" 26, "	1·00	0·06
Aylesbury, collected 2nd July, 1879 .. ..	" 29, "	0·96	0·06
	Sept. 4, "	0·045	0·035

The ammonia in the Birmingham effluent rose in twenty-three days from 3·222 to 4·2, then began to fall; Burnley in twenty-seven days from 1·33 to 1·92; Aylesbury did not change in a week; Aldershot (dry) may be said not to have changed in twenty-five days.

## APPENDIX.

ANALYSES of SPECIMENS of WATERS from SEWERAGE WORKS, made by Dr. Angus Smith, expressed in Parts per 100,000.

SAMPLES from BURNLEY, collected 16th June, 1879.

	Organic Carbon.	Free Ammonia.	Albuminoid Ammonia.	Residual Ammonia.	Total Ammonia.	Nitric Acid.	Sulphuric Acid.	Chlorine.	Mineral Solids.	Volatile Solids.	Total Solids.	Alkalinity as SO <sub>3</sub> .	Hardness.	
													Before Boiling.	After Boiling.
Stream above sewage	0.476	0.025	0.024	0.075	0.124	0.50	3.26	1.28	17.0	3.0	20.0	7.50	10.81	7.78
.. .. .	..	..	..	..	..	..	..	..	..	..	..	..	..	..
Ditto below ditto	0.987	0.236	0.070	0.219	0.525	0.56	4.12	1.90	18.5	6.5	25.0	9.00	12.64	8.22
Crude sewage	20.33	1.45	1.20	3.703	6.353	..	6.35	5.12	49.0	148.0	197.0	13.00	..	..
Effluent from sewage	3.737	1.33	0.305	2.503	4.138	1.20	7.38	5.06	40.0	14.0	54.0	13.00	20.92	17.16
.. .. .	..	..	..	..	..	..	..	..	..	..	..	..	..	..

SAMPLES from BIRMINGHAM, collected 23rd June, 1879.

	Organic Carbon.	Free Ammonia.	Albuminoid Ammonia.	Residual Ammonia.	Total Ammonia.	Nitric Acid.	Sulphuric Acid.	Chlorine.	Mineral Solids.	Volatile Solids.	Total Solids.	Hardness.		
												Before Boiling.	After Boiling.	
Crude sewage .. .. .	20.44	2.70	1.05	5.46	9.21	None	25.23	24.16	102.0	75.0	177.0	13.83	45.0	44.0
Effluent from settling tanks	4.09	3.22	0.66	3.93	7.81	2.13	22.65	15.78	74.0	26.5	100.5	11.32	39.0	38.4
Effluent after irrigation ..	2.303	1.275	0.21	2.109	3.594	1.19	18.19	11.46	88.5	24.0	112.5	97.77	66.8	29.22

SAMPLES from COVENTRY, collected 24th June, 1879.

	Organic Carbon.	Free Ammonia.	Albuminoid Ammonia.	Residual Ammonia.	Total Ammonia.	Nitric Acid.	Sulphuric Acid.	Chlorine.	Mineral Solids.	Volatile Solids.	Total Solids.	Hardness.		
												Before Boiling.	After Boiling.	
Crude sewage .. .. .	11.33	2.58	1.700	5.09	9.370	None	11.33	6.85	59.0	31.0	90.0	25.35	32.80	9.85
Effluent from settling tanks (filtered) .. .. .	1.418	2.40	0.245	0.511	3.156	None	7.21	6.30	55.0	16.0	71.0	22.94	37.15	15.62
Effluent after irrigation (drain out of order) ..	0.587	2.12	0.205	0.895	3.220	1.22	13.21	5.73	58.0	19.0	77.0	12.62	35.45	17.65

SAMPLE from COVENTRY, collected 10th July, 1879.

	Organic Carbon.	Free Ammonia.	Albuminoid Ammonia.	Residual Ammonia.	Total Ammonia.	Nitric Acid.	Sulphuric Acid.	Chlorine.	Mineral Solids.	Volatile Solids.	Total Solids.	Hardness.		
												Before Boiling.	After Boiling.	
Effluent after irrigation ..	0.618	0.52	0.061	0.009	0.590	1.62	13.39	4.99	58.5	12.0	70.5	21.0	40.70	19.72

SAMPLES from ALDERSHOT, collected 1st July, 1879 (wet weather).

	Organic Carbon.	Free Ammonia.	Albuminoid Ammonia.	Residual Ammonia.	Total Ammonia.	Nitric Acid.	Sulphuric Acid.	Chlorine.	Mineral Solids.	Volatile Solids.	Total Solids.	Hardness.		
												Before Boiling.	After Boiling.	
Crude sewage .. .. .	16.90	3.660	1.750	3.813	9.223	Traces	2.04	4.38	41.0	32.0	73.0	9.40	6.71	3.38
Effluent "A" from sewage farm .. .. .	..	0.920	0.276	0.803	1.999	2.69	5.14	4.54	24.0	16.0	28.0	2.50	6.57	6.29
Effluent "B" from sewage farm .. .. .	2.282	0.880	0.200	0.788	1.868	1.59	1.89	3.14	15.0	11.0	26.0	1.90	5.00	4.57
Effluent "C" from sewage farm .. .. .	2.240	0.440	0.144	0.318	0.992	4.08	2.40	3.20	20.0	14.5	34.5	0.70	7.86	6.86



Analyses of the Ingleton lime used at the Bradford Corporation Sewage Works, and of two other descriptions found to be unsuitable:—

	Ingleton.	Shipley.	Knottingly.
Lime .. .. .	94·78	65·94	60·76
Magnesia .. .. .	·36	·99	·90
Oxide of iron .. .. .	·14	·28	·70
Phosphoric acid .. .. .	trace	·48	·06
Sulphuric acid .. .. .	trace	3·46	1·63
Carbonic acid .. .. .	3·05	6·40	17·54
Alumina .. .. .	·75	3·75	1·75
Silica .. .. .	·95	7·50	8·75
Water .. .. .	..	10·36	7·63
	100·03	99·16	99·72

NOTE.—The Shipley and Knottingly lime had been kept for some time, and had absorbed some carbonic acid and water.



TABLE OF TOWNS.

Name of Town.	Population.	Daily flow of Sewage in gallons.*	Annual Rateable Value.	Area of Land irrigated. Acres.	Number of Inhabitants to each acre irrigated. †	Annual Cost, exclusive of Cost of Management. ‡	Cost per head of the Population per annum. §		Cost per million gallons of Sewage.		Annual Cost in the pound. ¶		
							£	d.	£	s.	£	d.	£
Aldershot †	11,615	200,000	26,517	2½	121	412	0	8½	3	10	7	0	2½
Abingdon ..	5,943	108,000	14,741	49	84	599	0	8½	2	6	10½	0	2½
Banbury ..	11,718	320,000	34,104	138	92	6,296	1	6	7	16	9½	0	6½
Bedford ..	16,851	700,000	65,000	183	121								
Blackburn ..	83,000	2,200,000	235,127	684	91	132	0	0½	0	5	9½	0	0½
Cheltenham ..	41,923	1,250,000	217,849	{131 330}	185	784	0	10½	4	5	11	0	3½
Chorley ..	18,000	500,000	54,407	97	78	5,368	5	4½	16	6	9½	1	9½
Crewe ..	20,000	900,000	59,705	257	108	4,311	1	6	3	18	9	0	3½
Croydon ..	57,000	3,000,000	275,000	525	71	1,000	1	1	3	18	3½	0	3½
Doncaster ..	18,750	700,000	68,721	262	207	658	0	11½	3	12	2	0	3½
Kendal ..	13,442	500,000	44,600	65	114	2,880	2	11½	7	0	11	1	0½
Kidderminster ..	19,463	1,120,000	53,196	170	51	2,086	1	8½	7	2	10½	0	4½
Leamington ..	24,000	800,000	113,400	469	121	4,500	1	10½	10	5	5½	0	8
Merthyr Tydvil ..	48,500	1,200,000	135,000	{380 20}	137	3,805	1	8½	10	8	6	0	7½
Northampton ..	45,000	1,000,000	117,089	327	103	12,763	3	0½	5	16	6½	1	1½
Norwich ..	84,000	6,000,000	225,000	811	107	262	0	7½	1	15	10	0	1½
Rugby ..	8,400	400,000	45,000	78	78	4,144	3	7½	17	9	4	0	6½
Tunbridge Wells ..	23,000	650,000	142,914	295	81	1,667	3	0	6	10	5½	0	9½
Warwick ..	11,000	700,000	43,339	135	116	2,176	1	9½	8	4	11	0	3½
West Derby ..	24,100	723,000	163,000	207	143								
Wigan ..	39,111	2,000,000	121,000	273	206								
Wolverhampton ..	68,279	2,000,000	216,081	330	101								
Wrexham ..	8,537	300,000	32,000	84									

\* Average daily flow of sewage per head of population, 39 gallons.

† The sewage is only applied to the land two days out of seven.

‡ Average population to each acre, 111.

§ Average cost per head of population, 1s. 10½d.

|| Average cost per million gallons, 26 10s. 2½d.

¶ Average cost in the pound, 6d.

BOOKS RELATING  
TO  
APPLIED SCIENCE,

PUBLISHED BY

E. & F. N. SPON,  
LONDON: 46, CHARING CROSS.  
NEW YORK: 446, BROOME STREET.

---

*The Electric Light in its Practical Application.* By  
PAGET HIGGS, LL.D., D.Sc., Telford Prizeman, and Associate Member  
of the Institution of Civil Engineers. *With 94 illustrations, 240 pages.*  
Demy 8vo, cloth, 9s.

CONTENTS :

Introductory—Lamps or Burners Employing the Voltaic Arc—Electric “Candles” and  
Candle Lamps—Lighting by Incandescence—Magneto and Dynamo-electric Machines—  
Mechanical Efficiency of Electric Light Machines—Simple Mathematical Considerations  
Concerning Electric Lighting—Electric Regulators—Commercial Aspect of Electric Lighting  
—Division of the Electric Light—Maritime and Military Aspects—Various Applications of  
the Electric Light—Electric Carbons.

*Algebra Self-Taught.* By W. P. HIGGS; M.A.,  
D.Sc., LL.D., Assoc. Inst. C.E., Author of ‘A Handbook of the Differ-  
ential Calculus,’ etc. Crown 8vo, cloth, 2s. 6d.

CONTENTS :

Symbols and the Signs of Operation—The Equation and the Unknown Quantity—  
Positive and Negative Quantities—Multiplication—Involution—Exponents—Negative Expo-  
nents—Roots, and the Use of Exponents as Logarithms—Logarithms—Tables of Logarithms  
and Proportionate Parts—Transformation of System of Logarithms—Common Uses of  
Common Logarithms—Compound Multiplication and the Binomial Theorem—Division,  
Fractions and Ratio—Continued Proportion—The Series and the Summation of the Series—  
Limit of Series—Square and Cube Roots—Equations—List of Formulæ, etc.

*Progressive Lessons in Applied Science.* By EDWARD  
SANG, F.R.S.E. Crown 8vo, cloth, each Part, 3s.

Part 1. Geometry on Paper—Part 2. Solidity, Weight, and Pressure—Part 3. Trigo-  
nometry, Vision, and Surveying Instruments.

*On Designing Belt Gearing.* By E. J. COWLING WELCH, Mem. Inst. Mèch. Engineers, Author of 'Designing Valve Gearing.' Fcap. 8vo, sewed, 6d.

*Arbitrations: a Text-book for Surveyors in Tabulated Form.* By BANISTER FLETCHER, F.R.I.B.A., Author of 'Model Houses,' etc. Crown 8vo, cloth, 5s.

CONTENTS :

What matters may be submitted to Arbitration—Of the Submission—Of Revocation—Who may Arbitrate—Powers of the Arbitrators—Of Joint Arbitrators and Umpires—Of Evidence—Of the Award—Of Costs and Charges—Advice to Plaintiffs and Defendants—Appendix of Forms.

*A Handbook of Formulae, Tables, and Memoranda, for Architectural Surveyors and others engaged in Building.* By J. T. HURST, C.E. Twelfth edition. Royal 32mo, roan, 5s.

CONTAINING :

Formulae and Tables for the Strength of Materials, Roofs, Water Supply, Drainage, Gas, and other matters useful to Architects and Builders—Information connected with Sanitary Engineering—Memoranda on the several Trades used in Building, including a Description of Materials and Analyses for Prices of Builders' Work—The Practice of Builders' Measurement—Mensuration and the Division of Land—Tables of the Weights of Iron and other Building Materials—Constants of Labour—Valuation of Property—Summary of the Practice in Dilapidations—Scale of Professional Charges for Architects and Surveyors—Tables of English and French Weights and Measures.

"It is no disparagement to the many excellent publications we refer to, to say that in our opinion this little pocket-book of Hurst's is the very best of them all, without any exception. It would be useless to attempt a recapitulation of the contents, for it appears to contain almost everything that anyone connected with building could require, and, best of all, made up in a compact form for carrying in the pocket, measuring only 3 in. by 3 in., and about  $\frac{1}{4}$  in. thick, in a limp cover. We congratulate the author on the success of his laborious and practically compiled little book, which has received unqualified and deserved praise from every professional person to whom we have shown it."—*The Dublin Builder.*

*A Treatise on the Use of Belting for the Transmission of Power;* with numerous Illustrations of approved and actual methods of arranging Main Driving and Quarter-Twist Belts, and of Belt Fastenings. Examples and Rules in great number for Exhibiting and Calculating the Size and Driving Power of Belts. Plain, Particular, and Practical Directions for the Treatment, Care, and Management of Belts. Descriptions of many varieties of Beltings, together with chapters on the Transmission of Power by Ropes; by Iron and Wood Frictional Gearing; on the Strength of Belting Leather; and on the Experimental Investigations of Morin, Briggs, and others for determining the Friction of Belts under different Tensions, which are presented clearly and fully, with the Text and Tables unabridged. By JOHN H. COOPER, M.E. 1 vol., demy 8vo, cloth, 15s.

*Narrow Gauge Railways.* By C. E. SPOONER, C.E., F.G.S. *With plates.* Second edition, 8vo, cloth, 15s.

*Researches on the Action of the Blast Furnace.* By CHARLES SCHINZ. Translated from the German by W. H. Maw and Moritz Müller. *Plates*, crown 8vo, cloth, 8s. 6d.

*Spons' Builders' Pocket-Book of Prices and Memoranda.* Edited by W. YOUNG, Architect. Royal 32mo, roan, 4s. 6d.; or cloth, red edges, 3s. 6d. *Published annually.* Seventh edition in the press.

*Long-Span Railway Bridges*, comprising Investigations of the Comparative Theoretical and Practical Advantages of the various adopted or proposed Type Systems of Construction, with numerous Formulæ and Tables giving the weight of Iron or Steel required in Bridges from 300 feet to the limiting Spans; to which are added similar Investigations and Tables relating to Short-span Railway Bridges. Second and revised edition. By B. BAKER, Assoc. Inst. C.E. *Plates*, crown 8vo, cloth, 5s.

*The Builder's Clerk: a Guide to the Management of a Builder's Business.* By THOMAS BALES. Fcap. 8vo, cloth, 1s. 6d.

*The Cabinet Maker: being a Collection of the most approved Designs in the Mediæval, Louis-Seize, and Old-English styles, for the use of Cabinet Makers, Carvers, etc.* By R. CHARLES. 96 *plates*, folio, half-bound, 21s.

*The Elementary Principles of Carpentry.* By THOMAS TREDGOLD. Revised from the original edition, and partly re-written, by JOHN THOMAS HURST. Contained in 517 pages of letter-press, and *illustrated with 48 plates and 150 wood engravings.* Second edition, crown 8vo, cloth, 18s.

Section I. On the Equality and Distribution of Forces—Section II. Resistance of Timber—Section III. Construction of Floors—Section IV. Construction of Roofs—Section V. Construction of Domes and Cupolas—Section VI. Construction of Partitions—Section VII. Scaffolds, Staging, and Gantries—Section VIII. Construction of Centres for Bridges—Section IX. Cofferdams, Shoring, and Strutting—Section X. Wooden Bridges and Viaducts—Section XI. Joints, Straps, and other Fastenings—Section XII. Timber.

*Engineering Notes.* By FRANK ROBERTSON, Fellow Roy. Astron. Soc., late first Lieut. R.E., and Civil Engineer Public Works Department in India. 8vo, cloth, 12s. 6d.

The object of this work is to supply an exhaustive digest of all that is known on each subject, so far as is necessary and sufficient for an Engineer in practice, especially in India.

*A Practical Treatise on Casting and Founding*, including descriptions of the modern machinery employed in the art. By N. E. SPRETSON, Engineer. With 82 plates drawn to scale, 412 pp. Demy 8vo, cloth, 18s.

*A Pocket-Book for Chemists, Chemical Manufacturers, Metallurgists, Dyers, Distillers, Brewers, Sugar Refiners, Photographers, Students, etc., etc.* By THOMAS BAYLEY, Assoc. R.C. Sc. Ireland, Analytical and Consulting Chemist, Demonstrator of Practical Chemistry, Analysis, and Assaying, in the Mining School, Bristol. Royal 32mo, roan, gilt edges, 5s.

SYNOPSIS OF CONTENTS :

Atomic Weights and Factors—Useful Data—Chemical Calculations—Rules for Indirect Analysis—Weights and Measures—Thermometers and Barometers—Chemical Physics—Boiling Points, etc.—Solubility of Substances—Methods of Obtaining Specific Gravity—Conversion of Hydrometers—Strength of Solutions by Specific Gravity—Analysis—Gas Analysis—Water Analysis—Qualitative Analysis and Reactions—Volumetric Analysis—Manipulation—Mineralogy—Assaying—Alcohol—Beer—Sugar—Miscellaneous Technological matter relating to Potash, Soda, Sulphuric Acid, Chlorine, Tar Products, Petroleum, Milk, Tallow, Photography, Prices, Wages, etc., etc.

*A Practical Treatise on Coal Mining.* By GEORGE G. ANDRÉ, F.G.S., Assoc. Inst. C.E., Member of the Society of Engineers. With 82 lithographic plates. 2 vols., royal 4to, cloth, 3l. 12s.

CONTENTS :

I. Practical Geology—II. Coal, its Mode of Occurrence, Composition, and Varieties—III. Searching for Coal—IV. Shaft-sinking—V. Driving of Levels, or Narrow Work—VI. Systems of Working—VII. Getting the Coal—VIII. Haulage—IX. Winding—X. Drainage—XI. Ventilation—XII. Incidental Operations—XIII. Surface Work—XIV. Management and Accounts—XV. Characteristics of the Coal Fields of Great Britain and America.

*The Electric Transmission of Power, its Present Position and Advantages.* By PAGET HIGGS, LL.D., D.Sc., Telford Prizeman, and Associate Member of the Institution of Civil Engineers. With numerous illustrations. Crown 8vo, cloth, 3s.

CONTENTS :

Dynamo-electric Machines—The Gramme Machine—The Brush Machine—The Wallace-Farmer and Siemens Machines—Efficiency of Dynamo-electric Machines—Practicability of the Transmission of Power by Electricity—Efficiency of Coupled Machines—Comparative Efficiency of Various Machines—Other Theoretical Considerations—Conclusions.

*The Clerk of Works: a Vade-Mecum for all engaged in the Superintendence of Building Operations.* By G. G. HOSKINS, F.R.I.B.A. Fcap. 8vo, cloth, 1s. 6d.

*Coffee Planting in Southern India and Ceylon.* By E. C. P. HULL. Crown 8vo, cloth, 9s.

*Spons' Information for Colonial Engineers.* Edited  
by J. T. HURST. Demy 8vo, sewed.

No. 1, Ceylon. By ABRAHAM DEANE, C.E. 2s. 6d.

CONTENTS:

Introductory Remarks—Natural Productions—Architecture and Engineering—Topography, Trade, and Natural History—Principal Stations—Weights and Measures, etc., etc.

No. 2. Southern Africa, including the Cape Colony, Natal, and the Dutch Republics. By HENRY HALL, F.R.G.S., F.R.C.I. With Map. 3s. 6d.

CONTENTS:

General Description of South Africa—Physical Geography with reference to Engineering Operations—Notes on Labour and Material in Cape Colony—Geological Notes on Rock Formation in South Africa—Engineering Instruments for Use in South Africa—Principal Public Works in Cape Colony: Railways, Mountain Roads and Passes, Harbour Works, Bridges, Gas Works, Irrigation and Water Supply, Lighthouses, Drainage and Sanitary Engineering, Public Buildings, Mines—Table of Woods in South Africa—Animals used for Draught Purposes—Statistical Notes—Table of Distances—Rates of Carriage, etc.

No. 3. India. By F. C. DANVERS, Assoc. Inst. C.E. With Map. 4s. 6d.

CONTENTS:

Physical Geography of India—Building Materials—Roads—Railways—Bridges—Irrigation—River Works—Harbours—Lighthouse Buildings—Native Labour—The Principal Trees of India—Money—Weights and Measures—Glossary of Indian Terms, etc.

*Tropical Agriculture; or, the Culture, Preparation, Commerce, and Consumption of the Principal Products of the Vegetable Kingdom, as furnishing Food, Clothing, Medicine, etc., and in their relation to the Arts and Manufactures; forming a practical treatise and Handbook of Reference for the Colonist, Manufacturer, Merchant, and Consumer, on the Cultivation, Preparation for Shipment, and Commercial Value, etc., of the various Substances obtained from Trees and Plants entering into the Husbandry of Tropical and Sub-Tropical Regions.* By P. L. SIMMONDS. Second edition, revised and improved, in one thick vol. 8vo, cloth, 17. 1s.

*Steel, its History, Manufacture, and Uses.* By J. S. JEANS, Secretary of the Iron and Steel Institute. Numerous engravings, 8vo, cloth. Nearly ready.

Section I., HISTORY OF STEEL: Chap. 1. History of Steel—2. Early History in England—3. Progress of Invention—4. History of Bessemer Process—5. Siemens-Martin Process—6. Other Steel-making Processes—7. Steel in America—8. Germany—9. France—10. Austria—11. Russia—12. Sweden—13. Other Countries. Section II., MANUFACTURE OF STEEL: Chap. 14. Cementation and other Methods—15. Manufacture by Bessemer Process—16. Siemens-Martin Process—17. Other Methods. Section III., CHEMICAL AND PHYSICAL PROPERTIES OF STEEL: Chap. 18. Phosphorus in Steel—19. The Use of Manganese—20. Spiegeleisen—21. Sulphur in Steel—22. Silicon in Steel—23. Tensile Strength of Steel—24. Mechanical Tests of Steel—25. Analysis of Steel. Section IV., USES OF STEEL: Chap. 26. Application of Steel to Railway Purposes—27. To Shipbuilding—28. To Bridge Building—29. To General Purposes—30. Guns and Armour Plates—31. Other Purposes.

*Compensations: a Text-book for Surveyors, in Tabulated Form.* By BANISTER FLETCHER. Crown 8vo, cloth, 5s.

CONTENTS:

The Varieties of Damage for which Claims may arise—Various Classes of Property—Points to be observed in Surveys—Notices to Treat—Nature of Damage for which Claims can and cannot be sustained—What Property can be compulsorily taken—When Entry on Property can and cannot be compulsorily made—Of Goodwill and Stock—and of the various Legal Methods of Settlement of Disputed Claims—together with Full and Explicit Instructions on the Methods of Valuing and of Making Claims; with Comments on Cases arising under the Metropolis Local Management and Metropolitan Buildings Acts; the whole given in a Practical and Comprehensive Form, supplemented by a copious Appendix, containing many Useful Forms and Precedents, and also Tables for the Valuation of Freeholds, Leaseholds, Reversions, and Life-Interests.

*Dilapidations: a Text-book for Architects and Surveyors, in Tabulated Form.* By BANISTER FLETCHER, Fellow Royal Inst. Brit. Arch. (Author of 'Model Houses'). Showing who are liable for Dilapidations, and the extent of the liability of Lessors, Lessees, Tenants at will, Tenants by elegit, Statute, Merchant, or Staple Tenants in fee simple, Tenants in tail, Tenants for life, Tenants for years without impeachment of Waste, Mortgagor, Mortgagee in possession, Yearly Tenants, Tenants in common, and joint Tenants, Rights of coparceners; also what are dilapidations and waste, and further fully instructs the surveyor how to take and value them, to which is added the duties of surveyors, with a table of legal cases, embracing the most recent, and illustrated throughout by examples drawn from the author's experience, and latest legal decisions. Crown 8vo, cloth, 5s.

*Spons' Dictionary of Engineering, Civil, Mechanical, Military, and Naval;* with technical terms in French, German, Italian, and Spanish, 3100 pp., and nearly 8000 engravings, in super-royal 8vo, in 8 divisions, 5l. 8s. Complete in 3 vols., cloth, 5l. 5s. Bound in a superior manner, half-morocco, top edge gilt, 3 vols., 6l. 12s.

See page 16.

*A Treatise on the Origin, Progress, Prevention, and Cure of Dry Rot in Timber;* with Remarks on the Means of Preserving Wood from Destruction by Sea-Worms, Beetles, Ants, etc. By THOMAS ALLEN BRITTON, late Surveyor to the Metropolitan Board of Works, etc., etc. Plates, crown 8vo, cloth, 7s. 6d.

*A General Table for facilitating the Calculation of Earthworks for Railways, Canals, etc.;* with a Table of Proportional Parts. By FRANCIS BASHFORTH, M.A., Fellow of St. John's College, Cambridge. In 8vo, cloth, with mahogany slide, 4s.

"This little volume should become the handbook of every person whose duties require even occasional calculations of this nature: were it only that it is more extensively applicable than any other in existence, we could cordially recommend it to our readers; but when they learn that the use of it involves only half the labour of all other Tables constituted for the same purposes, we offer the strongest of all recommendations—that founded on the value of time."—*Mechanic's Magazine.*

*A Handbook of Electrical Testing.* By H. R. KEMPE, Assoc. of the Society of Telegraph Engineers. *With Illustrations.* Fcap. 8vo, cloth, 5s.

*Electricity; its Theory, Sources, and Applications.* By JOHN T. SPRAGUE, Member of the Society of Telegraph Engineers. *With 91 woodcuts and 30 valuable Tables.* Crown 8vo, cloth, 8s.

*Electricity and the Electric Telegraph.* By GEORGE B. PRESCOTT. *With 564 woodcut illustrations,* 8vo, cloth, 18s.

*Electro-Telegraphy.* By FREDERICK S. BEECHEY, Telegraph Engineer, a Book for Beginners. Fcap. 8vo, cloth, 1s. 6d.

*Engineering Papers.* By GRAHAM SMITH. 8vo, cloth, 5s.

## CONTENTS:

Mortar: "Miller Prize" Paper—Practical Ironwork: "Miller Prize" Paper—Retaining Walls: Paper read at the Edinburgh and Leith Engineers' Society. *With Addenda and Discussions to each.*

*Spons' Engineers' and Contractors' Illustrated Book of Prices of Machines, Tools, Ironwork, and Contractors' Material.* Royal 8vo, cloth, 7s. 6d. Third edition nearly ready.

*The Gas Consumer's Handy Book.* By WILLIAM RICHARDS, C.E. 18mo, sewed, 6d.

*A Practical Treatise on Natural and Artificial Concrete, its Varieties and Constructive Adaptations.* By HENRY REID, Author of the 'Science and Art of the Manufacture of Portland Cement.' *With numerous woodcuts and plates,* 8vo, cloth, 15s.

*The Gas Analyst's Manual.* By F. W. HARTLEY, Assoc. Inst. C.E., etc. *With numerous illustrations.* Crown 8vo, cloth, 6s.

*The French-Polisher's Manual.* By a French-Polisher; containing Timber Staining, Washing, Matching, Improving, Painting, Imitations, Directions for Staining, Sizing, Embodying, Smoothing, Spirit Varnishing, French-Polishing, Directions for Re-polishing. Third edition, royal 32mo, sewed, 6d.



*A Pocket-Book of Useful Formulæ and Memoranda for Civil and Mechanical Engineers.* By GUILFORD L. MOLESWORTH, Mem. Inst. C. E., Consulting Engineer to the Government of India for State Railways. Nineteenth edition, with a valuable contribution on Telegraphs by R. S. BROUGH and Dr. PAGET HIGGS. 32mo, roan, 6s. Ditto, interleaved with ruled Paper for Office use, 9s. Ditto, printed on India paper, 6s.

SYNOPSIS OF CONTENTS:

Surveying, Levelling, etc.—Strength and Weight of Materials—Earthwork, Brickwork, Masonry, Arches, etc.—Struts, Columns, Beams, and Trusses—Flooring, Roofing, and Roof Trusses—Girders, Bridges, etc.—Railways and Roads—Hydraulic Formulæ—Canals, Sewers, Waterworks, Docks—Irrigation and Breakwaters—Gas, Ventilation, and Warming—Heat, Light, Colour, and Sound—Gravity: Centres, Forces, and Powers—Millwork, Teeth of Wheels, Shafting, etc.—Workshop Recipes—Sundry Machinery—Animal Power—Steam and the Steam Engine—Water-power, Water-wheels, Turbines, etc.—Wind and Windmills—Steam Navigation, Ship Building, Tonnage, etc.—Gunnery, Projectiles, etc.—Weights, Measures, and Money—Trigonometry, Conic Sections, and Curves—Telegraphy—Mensuration—Tables of Areas and Circumference, and Arcs of Circles—Logarithms, Square and Cube Roots, Powers—Reciprocals, etc.—Useful Numbers—Differential and Integral Calculus—Algebraic Signs—Telegraphic Construction and Formulæ.

"Most of our readers are already acquainted with Molesworth's Pocket-book, and not a few, we imagine, are indebted to it for valuable information, or for refreshers of the memory. The book has been re-arranged, the supplemental formulæ and tables added since the first issue having now been incorporated with the body of the book in their proper positions, the whole making a handy size for the pocket. Every care has been taken to ensure correctness, both clerically and typographically, and the book is an indispensable *vade-mecum* for the mechanic and the professional man."—*English Mechanic*.

*Spons' Tables and Memoranda for Engineers;* selected and arranged by J. T. HURST, C.E., Author of 'Architectural Surveyors' Handbook,' 'Hurst's Tredgold's Carpentry,' etc. 64mo, roan, gilt edges, third edition, revised and improved, 1s. Or in cloth case, 1s. 6d.

This work is printed in a pearl type, and is so small, measuring only 2½ in. by 1½ in. by ¼ in. thick, that it may be easily carried in the waistcoat pocket.

"It is certainly an extremely rare thing for a reviewer to be called upon to notice a volume measuring but 2½ in. by 1½ in., yet these dimensions faithfully represent the size of the handy little book before us. The volume—which contains 118 printed pages, besides a few blank pages for memoranda—is, in fact, a true pocket-book, adapted for being carried in the waistcoat pocket, and containing a far greater amount and variety of information than most people would imagine could be compressed into so small a space. . . . The little volume has been compiled with considerable care and judgment, and we can cordially recommend it to our readers as a useful little pocket companion."—*Engineering*.

*Analysis, Technical Valuation, Purification and Use of Coal Gas.* By the Rev. W. R. BOWDITCH, M.A. With wood engravings, 8vo, cloth, 12s. 6d.

Condensation of Gas—Purification of Gas—Light—Measuring—Place of Testing Gas—Test Candles—The Standard for Measuring Gas—light—Test Burners—Testing Gas for Sulphur—Testing Gas for Ammonia—Condensation by Bromine—Gravimetric Method of taking Specific Gravity of Gas—Carbureting or Naphthalizing Gas—Acetylene—Explosions of Gas—Gnawing of Gaspipes by Rats—Pressure as related to Public Lighting, etc.

*Hops, their Cultivation, Commerce, and Uses in various Countries.* By P. L. SIMMONDS. Crown 8vo, cloth, 4s. 6d.

*A Practical Treatise on the Manufacture and Distribution of Coal Gas.* By WILLIAM RICHARDS. Demy 4to, with numerous wood engravings and large plates, cloth, 28s.

SYNOPSIS OF CONTENTS :

Introduction—History of Gas Lighting—Chemistry of Gas Manufacture, by Lewis Thompson, Esq., M.R.C.S.—Coal, with Analyses, by J. Paterson, Lewis Thompson, and G. R. Hislop, Esqrs.—Retorts, Iron and Clay—Retort Setting—Hydraulic Main—Condensers—Exhausters—Washers and Scrubbers—Purifiers—Purification—History of Gas Holder—Tanks, Brick and Stone, Composite, Concrete, Cast-iron, Compound Annular Wrought-iron—Specifications—Gas Holders—Station Meter—Governor—Distribution—Mains—Gas Mathematics, or Formulæ for the Distribution of Gas, by Lewis Thompson, Esq.—Services—Consumers' Meters—Regulators—Burners—Fittings—Photometer—Carburization of Gas—Air Gas and Water Gas—Composition of Coal Gas, by Lewis Thompson, Esq.—Analyses of Gas—Influence of Atmospheric Pressure and Temperature on Gas—Residual Products—Appendix—Description of Retort Settings, Buildings, etc., etc.

*Practical Geometry and Engineering Drawing*; a Course of Descriptive Geometry adapted to the Requirements of the Engineering Draughtsman, including the determination of cast shadows and Isometric Projection, each chapter being followed by numerous examples; to which are added rules for Shading Shade-lining, etc., together with practical instructions as to the Lining, Colouring, Printing, and general treatment of Engineering Drawings, with a chapter on drawing Instruments. By GEORGE S. CLARKE, Lieut. R.E., Instructor in Mechanical Drawing, Royal Indian Engineering College, Cooper's Hill. 20 plates, 4to, cloth, 15s.

*The Elements of Graphic Statics.* By Professor KARL VON OTT, translated from the German by G. S. CLARKE, Lieut. R.E., Instructor in Mechanical Drawing, Royal Indian Engineering College, Cooper's Hill. Crown 8vo, cloth, 5s.

*A Practical Treatise on Heat, as applied to the Useful Arts*; for the Use of Engineers, Architects, etc. By THOMAS BOX. Second edition, revised and enlarged, crown 8vo, cloth, 12s. 6d.

*The New Formula for Mean Velocity of Discharge of Rivers and Canals.* By W. R. KUTTER, translated from articles in the 'Cultur-Ingenieur.' By LOWIS D'A. JACKSON, Assoc. Inst. C.E. 8vo, cloth, 12s. 6d.

*Hydraulics of Great Rivers; being Observations and Surveys on the Largest Rivers of the World.* By J. J. REVY. Imp. 4to, cloth, with eight large plates and charts, 2l. 2s.

*Practical Hydraulics*; a Series of Rules and Tables for the use of Engineers, etc., etc. By THOMAS BOX. Fifth edition, numerous plates, post 8vo, cloth, 5s.

*The Indicator Diagram Practically Considered.* By N. P. BURGH, Engineer. *Numerous illustrations, fifth edition.* Crown 8vo, cloth, 6s. 6d.

"This volume possesses one feature which renders it almost unique; this feature is the mode in which it is illustrated. It is not difficult to take a diagram if the instrument is once set, and the setting with stationary engines is occasionally easy enough, but circumstances continually arise under which the young engineer is completely at a loss as to how to obtain a diagram. All uncertainty will be removed by referring to the book under consideration: here we have drawings of the arrangements to be adopted under every conceivable circumstance, drawings, we may add, illustrating the practice of the best engineers of the day."—*Engineer.*

*Link-Motion and Expansion Gear Practically Considered.* By N. P. BURGH, Engineer. *Illustrated with 90 plates and 229 wood engravings, small 4to, half-morocco, 2l. 2s.*

*The Mechanician and Constructor for Engineers,* comprising Forging, Planing, Lining, Slotting, Shaping, Turning, Screw Cutting, etc. By CAMERON KNIGHT. *Containing 96 plates, 1147 illustrations, and 397 pages of letterpress, 4to, half-morocco, 2l. 12s. 6d.*

*The Essential Elements of Practical Mechanics;* based on the Principle of Work, designed for Engineering Students. By OLIVER BYRNE, formerly Professor of Mathematics, College for Civil Engineers. Third edition, *illustrated by numerous wood engravings, post 8vo, cloth, 7s. 6d.*

#### CONTENTS :

Chap. 1. How Work is Measured by a Unit, both with and without reference to a Unit of Time—Chap. 2. The Work of Living Agents, the Influence of Friction, and introduces one of the most beautiful Laws of Motion—Chap. 3. The principles expounded in the first and second chapters are applied to the Motion of Bodies—Chap. 4. The Transmission of Work by simple Machines—Chap. 5. Useful Propositions and Rules.

*The Practical Millwright's and Engineer's Ready Reckoner;* or Tables for finding the diameter and power of cog-wheels, diameter, weight, and power of shafts, diameter and strength of bolts, etc. By THOMAS DIXON. Fourth edition, 12mo, cloth, 3s.

#### CONTENTS :

Diameter and Power of Wheels—Diameter, Weight, and Power of Shafts—Multipliers for Steam used Expansively—Diameters and Strength of Bolts—Size and Weight of Hexagonal Nuts—Speed of Governors for Steam Engines—Contents of Pumps—Working Barrels—Circumferences and Areas of Circles—Weight of Boiler Plates—French and English Weights and Measures, etc.

*The Principles of Mechanics and their Application to Prime Movers, Naval Architecture, Iron Bridges, Water Supply, etc.* By W. J. MILLAR, C.E., Secretary to the Institution of Engineers and Shipbuilders, Scotland. Crown 8vo, cloth, 4s. 6d.

*A Practical Treatise on Mill-gearing, Wheels, Shafts, Riggers, etc.*; for the use of Engineers. By THOMAS BOX. Crown 8vo, cloth, second edition, 7s. 6d.

*Mining Machinery: a Descriptive Treatise on the Machinery, Tools, and other Appliances used in Mining.* By G. G. ANDRÉ, F.G.S., Assoc. Inst. C.E., Mem. of the Society of Engineers. Royal 4to, uniform with the Author's Treatise on Coal Mining, containing 182 plates, accurately drawn to scale, with descriptive text, in 2 vols., cloth, 3l. 12s.

## CONTENTS :

Machinery for Prospecting, Excavating, Hauling, and Hoisting—Ventilation—Pumping—Treatment of Mineral Products, including Gold and Silver, Copper, Tin, and Lead, Iron, Coal, Sulphur, China Clay, Brick Earth, etc.

*The Pattern Maker's Assistant; embracing Lathe Work, Branch Work, Core Work, Sweep Work, and Practical Gear Construction, the Preparation and Use of Tools, together with a large collection of Useful and Valuable Tables.* By JOSHUA ROSE, M.E. With 250 illustrations. Crown 8vo, cloth, 10s. 6d.

*The Science and Art of the Manufacture of Portland Cement,* with observations on some of its constructive applications, with numerous illustrations. By HENRY REID, C.E., Author of 'A Practical Treatise on Concrete,' etc., etc. 8vo, cloth, 18s.

*The Draughtsman's Handbook of Plan and Map Drawing;* including instructions for the preparation of Engineering, Architectural, and Mechanical Drawings. With numerous illustrations in the text, and 33 plates (15 printed in colours). By G. G. ANDRÉ, F.G.S., Assoc. Inst. C.E. 4to, cloth, 15s.

## CONTENTS :

The Drawing Office and its Furnishings—Geometrical Problems—Lines, Dots, and their Combinations—Colours, Shading, Lettering, Bordering, and North Points—Scales—Plotting—Civil Engineers' and Surveyors' Plans—Map Drawing—Mechanical and Architectural Drawing—Copying and Reducing Trigonometrical Formulæ, etc., etc.

*The Railway Builder: a Handbook for Estimating the Probable Cost of American Railway Construction and Equipment.* By WILLIAM J. NICOLLS, Civil Engineer. Illustrated, full bound, pocket-book form, 7s. 6d.

*Rock Blasting: a Practical Treatise on the means employed in Blasting Rocks for Industrial Purposes.* By G. G. ANDRÉ, F.G.S., Assoc. Inst. C.E. With 56 illustrations and 12 plates, 8vo, cloth, 10s. 6d.

*Surcharged and different Forms of Retaining Walls.*

By J. S. TATE. *Cuts*, 8vo, sewed, 2s.

*A Treatise on Ropemaking as practised in public and*

*private Rope-yards*, with a Description of the Manufacture, Rules, Tables of Weights, etc., adapted to the Trade, Shipping, Mining, Railways, Builders, etc. By R. CHAPMAN, formerly foreman to Messrs. Huddart and Co., Limehouse, and late Master Ropemaker to H.M. Dockyard, Deptford. Second edition, 12mo, cloth, 3s.

*Sanitary Engineering; a Series of Lectures given*

*before the School of Engineering, Chatham.* Division I. Air.—Division II. Water.—Division III. The Dwelling.—Division IV. The Town and Village.—Division V. The Disposal of Sewage. Copiously illustrated. By J. BAILEY DENTON, C.E., F.G.S., Honorary Member of the Agricultural Societies of Norway, Sweden, and Hanover, and Author of the 'Farm Homesteads of England,' 'Village Sanitary Economy,' 'Storage of Water,' 'Sewage Farming,' etc. Royal 8vo, cloth, 25s.

*Sanitary Engineering: a Guide to the Construction*

of Works of Sewerage and House Drainage, with Tables for facilitating the calculations of the Engineer. By BALDWIN LATHAM, C.E., M. Inst. C.E., F.G.S., F.M.S., Past-President of the Society of Engineers. Second edition, with numerous plates and woodcuts, 8vo, cloth, 1l. 10s.

*A Practical Treatise on Modern Screw-Propulsion.*

By N. P. BURGH, Engineer. *Illustrated with 52 large plates and 103 woodcuts*, 4to, half-morocco, 2l. 2s.

*Screw Cutting Tables for Engineers and Machinists,*

giving the values of the different trains of Wheels required to produce Screws of any pitch, calculated by Lord Lindsay, M.P., F.R.S., F.R.A.S., etc. Royal 8vo, cloth, oblong, 2s.

*Screw Cutting Tables, for the use of Mechanical*

Engineers, showing the proper arrangement of Wheels for cutting the Threads of Screws of any required pitch, with a Table for making the Universal Gas-pipe Threads and Taps. By W. A. MARTIN, Engineer. Second edition, royal 8vo, oblong, cloth, 1s.

*Treatise on Valve-Gears, with special consideration*

of the Link-Motions of Locomotive Engines. By Dr. GUSTAV ZEUNER. Third edition, revised and enlarged, translated from the German, with the special permission of the author, by MORITZ MÜLLER. *Plates*, 8vo, cloth, 12s. 6d.

*Cleaning and Scouring*: a Manual for Dyers, Laundresses, and for Domestic Use. By S. CHRISTOPHER. 18mo, sewed, 6d.

*A Treatise on a Practical Method of Designing Slide-Valve Gears by Simple Geometrical Construction*, based upon the principles enunciated in Euclid's Elements, and comprising the various forms of Plain Slide-Valve and Expansion Gearing; together with Stephenson's, Gooch's, and Allan's Link-Motions, as applied either to reversing or to variable expansion combinations. By EDWARD J. COWLING WELCH, Memb. Inst. Mechanical Engineers. Crown 8vo, cloth. 6s.

*The Slide Valve practically considered*. By N. P. BURGH, Engineer. Ninth edition, with 88 illustrations, crown 8vo, cloth, 5s.

*A Pocket-Book for Boiler Makers and Steam Users*, comprising a variety of useful information for Employer and Workman, Government Inspectors, Board of Trade Surveyors, Engineers in charge of Works and Slips, Foremen of Manufactories, and the general Steam-using Public. By MAURICE JOHN SEXTON. Royal 32mo, roan, gilt edges, 5s.

*Modern Compound Engines*; being a Supplement to Modern Marine Engineering. By N. P. BURGH, Mem. Inst. Mech. Eng. Numerous large plates of working drawings, 4to, cloth, 18s.

The following Firms have contributed Working Drawings of their best and most modern examples of Engines fitted in the Royal and Mercantile Navies: Messrs. Maudslay, Rennie, Watt, Dudgeon, Humphreys, Ravenhill, Jackson, Perkins, Napier, Elder, Laird, Day, Allibon.

*A Practical Treatise on the Steam Engine*, containing Plans and Arrangements of Details for Fixed Steam Engines, with Essays on the Principles involved in Design and Construction. By ARTHUR RIGG, Engineer, Member of the Society of Engineers and of the Royal Institution of Great Britain. Demy 4to, copiously illustrated with woodcuts and 96 plates, in one Volume, half-bound morocco, 2l. 2s.

This work is not, in any sense, an elementary treatise, or history of the steam engine, but is intended to describe examples of Fixed Steam Engines without entering into the wide domain of locomotive or marine practice. To this end illustrations will be given of the most recent arrangements of Horizontal, Vertical, Beam, Pumping, Winding, Portable, Semi-portable, Corliss, Allen, Compound, and other similar Engines, by the most eminent Firms in Great Britain and America. The laws relating to the action and precautions to be observed in the construction of the various details, such as Cylinders, Pistons, Piston-rods, Connecting-rods, Cross-heads, Motion-blocks, Eccentrics, Simple, Expansion, Balanced, and Equilibrium Slide-valves, and Valve-gearing will be minutely dealt with. In this connection will be found articles upon the Velocity of Reciprocating Parts and the Mode of Applying the Indicator, Heat and Expansion of Steam Governors, and the like. It is the writer's desire to draw illustrations from every possible source, and give only those rules that present practice deems correct.

*Practical Treatise on Steam Boilers and Boiler Making.* By N. P. BURGH, Mem. Inst. Mec. Eng. Illustrated by 1163 wood engravings and 50 large folding plates of working drawings, royal 4to, half-morocco, 3l. 13s. 6d.

BARLOW'S *Tables of Squares, Cubes, Square Roots, Cube Roots, Reciprocals of all Integer Numbers up to 10,000.* Post 8vo, cloth, 6s.

CAMUS (M.) *Treatise on the Teeth of Wheels*, demonstrating the best forms which can be given to them for the purposes of Machinery, such as Mill-work and Clock-work, and the art of finding their numbers, translated from the French. Third edition, carefully revised and enlarged, with details of the present practice of Millwrights, Engine Makers, and other Machinists. By ISAAC HAWKINS. Illustrated by 18 plates, 8vo, cloth, 5s.

*The Chemistry of Sulphuric Acid Manufacture.* By HENRY ARTHUR SMITH. Cuts, crown 8vo, cloth, 4s. 6d.

CONTENTS :

Ground Plan of Kilns for Burning Sulphur Ores—Section of Pyrites Furnace—On the Presence of Arsenic—Methods for Removal of Arsenic—An Experimental Examination of the Circumstances which determine the Action of the Gases in the Lead Chamber—On the Distribution of Gases in the Lead Chamber—On the Temperature at which Nitric Acid acts upon Sulphurous Acid—On the Distribution of Heat in the Lead Chamber—An Inquiry into the Best Form of Lead Chamber, etc.

*A Practical Treatise on the Science of Land and Engineering Surveying, Levelling, Estimating Quantities, etc.*, with a general description of the several Instruments required for Surveying, Levelling, Plotting, etc. By H. S. MERRETT. 41 fine plates with Illustrations and Tables, royal 8vo, cloth, third edition, 12s. 6d.

PRINCIPAL CONTENTS :

Part 1. Introduction and the Principles of Geometry. Part 2. Land Surveying; comprising General Observations—The Chain—Offsets Surveying by the Chain only—Surveying Hilly Ground—To Survey an Estate or Parish by the Chain only—Surveying with the Theodolite—Mining and Town Surveying—Railroad Surveying—Mapping—Division and Laying out of Land—Observations on Enclosures—Plane Trigonometry. Part 3. Levelling—Simple and Compound Levelling—The Level Book—Parliamentary Plan and Section—Levelling with a Theodolite—Gradients—Wooden Curves—To Lay out a Railway Curve—Setting out Widths. Part 4. Calculating Quantities generally for Estimates—Cuttings and Embankments—Tunnels—Brickwork—Ironwork—Timber Measuring. Part 5. Description and Use of Instruments in Surveying and Plotting—The Improved Dumpy Level—Troughton's Level—The Prismatic Compass—Proportional Compass—Box Sextant—Vernier—Pantagraph—Merrett's Improved Quadrant—Improved Computation Scale—The Diagonal Scale—Straight Edge and Sector. Part 6. Logarithms of Numbers—Logarithmic Sines and Co-Sines, Tangents and Co-Tangents—Natural Sines and Co-Sines—Tables for Earthwork, for Setting out Curves, and for various Calculations, etc., etc., etc.

*Laying and Repairing Electric Telegraph Cables.* By Capt. V. HOSKIER, Royal Danish Engineers. Crown 8vo, cloth, 3s. 6d.

*A Pocket-Book of Practical Rules for the Proportions of Modern Engines and Boilers for Land and Marine purposes.* By N. P. BURGH. Sixth edition, revised, with Appendix, royal 32mo, roan, 4s. 6d.

Details of High-Pressure Engine, Beam Engine, Condensing, Marine Screw Engines, Oscillating Engines, Valves, etc., Land and Marine Boilers, Proportions of Engines produced by the Rules, Proportions of Boilers, etc.

*Table of Logarithms of the Natural Numbers, from 1 to 108,000.* By CHARLES BABBAGE, Esq., M.A. Stereotyped edition, royal 8vo, cloth, 7s. 6d.

To ensure the correctness of these Tables of Logarithms, they were compared with Callett's, Vega's, Hutton's, Briggs', Gardiner's, and Taylor's Tables of Logarithms, and carefully read by nine different readers; and further, to remove any possibility of an error remaining, the stereotyped sheets were hung up in the Hall at Cambridge University, and a reward offered to anyone who could find an inaccuracy. So correct are these Tables, that since their first issue in 1827 no error has been discovered.

*The Steam Engine considered as a Heat Engine: a Treatise on the Theory of the Steam Engine, illustrated by Diagrams, Tables, and Examples from Practice.* By JAS. H. COTTERILL, M.A., Professor of Applied Mechanics in the Royal Naval College. 8vo, cloth, 12s. 6d.

*The Practice of Hand Turning in Wood, Ivory, Shell, etc., with Instructions for Turning such Work in Metal as may be required in the Practice of Turning in Wood, Ivory, etc., also an Appendix on Ornamental Turning.* By FRANCIS CAMPIN. Second edition, with wood engravings, crown 8vo, cloth, 6s. (a book for beginners).

CONTENTS :

On Lathes—Turning Tools—Turning Wood—Drilling—Screw Cutting—Miscellaneous Apparatus and Processes—Turning Particular Forms—Staining—Polishing—Spinning Metals—Materials—Ornamental Turning, etc.

*Health and Comfort in House Building, or Ventilation with Warm Air by Self-Acting Suction Power,* with Review of the mode of Calculating the Draught in Hot-Air Flues, and with some actual Experiments. By J. DRYSDALE, M.D., and J. W. HAYWARD, M.D. Second edition, with Supplement, demy 8vo, with plates, cloth, 7s. 6d.; the Supplement separate, 6d.

*Treatise on Watchwork, Past and Present.* By the Rev. H. L. NELTHROPP, M.A., F.S.A. Numerous illustrations, crown 8vo, cloth, 6s. 6d.

CONTENTS :

Definitions of Words and Terms used in Watchwork—Tools—Time—Historical Summary—On Calculations of the Numbers for Wheels and Pinions; their Proportional Sizes, Trains, etc.—Of Dial Wheels, or Motion Work—Length of Time of Going without Winding up—The Verge—The Horizontal—The Duplex—The Lever—The Chronometer—Repeating Watches—Keyless Watches—The Pendulum, or Spiral Spring—Compensation—Jewelling of Pivot Holes—Clerkenwell—Fallacies of the Trade—Incapacity of Workmen—How to Choose and Use a Watch, etc.



*Now in Course of Publication.*

To be completed in about 30 Monthly Parts, each Part containing 64 pp., with *numerous illustrations*, super-royal 8vo, price 2s. ; or in 5 Divisions, cloth, price 13s. 6d. each.

DIVISION I. NOW READY.

# SPONS' ENCYCLOPÆDIA

OF THE

## INDUSTRIAL ARTS, MANUFACTURES, AND COMMERCIAL PRODUCTS.

EDITED BY GEO. G. ANDRÉ, F.G.S., ASSOC. INST. C.E.

*Now in Course of Publication.*

To be completed in about 18 Monthly Parts, each Part containing 64 pp., with *numerous illustrations*, super-royal 8vo, price 2s. ; or in 3 Divisions, cloth, price 13s. 6d. each.

DIVISION I. NOW READY.

# A SUPPLEMENT

TO

## SPONS' DICTIONARY OF ENGINEERING,

*Civil, Mechanical, Military, and Naval.*

EDITED BY ERNEST SPON, MEMB. SOC. ENGINEERS.

London: E. & F. N. SPON, 46, Charing Cross.

New York: 446, Broome Street.



